Purulia & Kharagpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of April 2021

	Outage	Restoration		Duration	of Outage Attributable	to	Reason of	%
			Inter-State		System constraint/			
Element Name	Date & Time	Date & Time	Transmission Licensee	Others	Natural calamity/ Militancy	Deemed Available	Outage	Availability
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Chaibasa-Kharagpur D/C line CKT- 2	02-04-2021	02-04-2021	1:06	0.00	00.0		Line was taken emergency shutdown for tree cutting work. Clearance for charging the line has been provided on 16:25 hrs but the line was charged at 17:32 hrs. Email copy attached for your ready reference	
400 kV Chaibasa-Kharagpur D/C line CKT- 2	14-04-2021	14-04-2021	3:22	0:00	0:00	0:00	Line tripped due to B-ph to earth fault	99.754%
400 kV Chaibasa-Kharagpur D/C line CKT- 2	18-04-2021	18-04-2021	1:34	0:00	0:00	0:00	Line was taken emergency shutdown for tree cutting work. Clearance for charging the line has been provided on 11:30 hrs but the line was charged at 12:14 hrs. Email copy attached for your ready reference	
					-	-		
	1	I	1	1	1	1	1	

Schedule I

Schedule II

Schedule III

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)		
Nil	Nil	Nil		
Nil	Nil	Nil		
Nil	Nil	Nil		

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2021

Element Name	Violation of R	egulation 5(a)	Violat	ion of Regulation 5(b)		
	% Actual %		Restoration time	Actual restoration	Compensation paid (in Rs)	
		Actual % Availability	prescribed	time	Compensation pair (in Ks)	
			(in days)	(in days)		
Nil	Nil	Nil	Nil	Nil	Nil	
Nil	Nil	Nil	Nil	Nil	Nil	
		Nil				