

Name of Transmission Licensee :- Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of April 2021

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Aligarh - Prithala(GPTL) Ckt	03-04-2021 09:43	03-04-2021 11:01	0:00:00	1:18:00	0:00:00	0:00:00	Line tripped from Prithala end due to DT received from Aligarh end.	99.98%
400kV Aligarh - Prithala(GPTL) Ckt	20-04-2021 10:46	20-04-2021 13:02	0:00:00	2:16:00	0:00:00	0:00:00	Line tripped at 10:46 hrs on 20/04/2021 from Prithala S/S due to 86 relay operated at Prithala S/S. Line was in idle charged condition from Aligarh substation.	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)				Compensation paid (in Rs)	
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)		Actual restoration time (in days)			
NIL	-	-	-	-				-
-	-	-	-	-				-
<b>Total</b>								