

Name of Transmission Licensee :- Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of August 2021

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Neemrana (PG)-Dhanonda (HVPNL)	09-08-2021 12:56	09-08-2021 20:42	0:00:00	0:00:00	0:00:00	7:46:00	Outage availed by SLDC Haryana to carry out protection audit at Dhanonda Sub-station. Line was charged at 23:23Hrs as powergrid was unable to charge the line due to Isolater Malfunctioning at their Neemrana S/s.	99.91%
400kV 125 MVAR Bus Reactor-1 at Prithala	07-08-2021 10:21	08-08-2021 16:20	0:00:00	0:00:00	0:00:00	29:59:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala	11-08-2021 11:23	21-08-2021 08:08	0:00:00	0:00:00	0:00:00	236:45:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Sohna R	16-08-2021 23:58	21-08-2021 08:14	0:00:00	0:00:00	0:00:00	104:16:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala	28-08-2021 00:22	01-09-2021 00:00	0:00:00	0:00:00	0:00:00	95:38:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation. The Bus reactor is still out on voltage regulation.	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of August 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)				Compensation paid (in Rs)	
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)				
NIL	-	-	-	-			-	
-	-	-	-	-			-	
Total								