

Name of Transmission Licensee :- Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of July 2021

Schedule I

Element Name	Outage Date Time	Restoration Date Time	Duration of Outage Attributable to				Reason of Outage	% Availability
			Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400/220kV 500 MVA ICT-2 at Prithala(GPTL)	05-07-2021 08:55	06-07-2021 01:10	16:15:00	0:00:00	0:00:00	0:00:00	GPTL took this shutdown for PRD-Replacemaent work.	99.84%
400/220kV 500 MVA ICT-2 at Sohna Road(GPTL)	07-07-2021 13:06	07-07-2021 22:04	8:58:00	0:00:00	0:00:00	0:00:00	GPTL taken emergency shutdown for Air Cell rectification work.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	01-07-2021 00:00	02-07-2021 17:22	0:00:00	0:00:00	0:00:00	41:22:00	Continuously in outage from previous month, Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	01-07-2021 00:00	25-07-2021 08:19	0:00:00	0:00:00	0:00:00	584:19:00	Continuously in outage from previous month, Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Sohna Road(GPTL)	01-07-2021 10:56	02-07-2021 17:13	0:00:00	0:00:00	0:00:00	30:17:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	04-07-2021 23:17	13-07-2021 18:21	0:00:00	0:00:00	0:00:00	211:04:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	16-07-2021 21:36	19-07-2021 03:41	0:00:00	0:00:00	0:00:00	54:05:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Sohna Road(GPTL)	16-07-2021 22:11	19-07-2021 03:37	0:00:00	0:00:00	0:00:00	53:26:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	23-07-2021 23:03	24-07-2021 07:15	0:00:00	0:00:00	0:00:00	8:12:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	24-07-2021 19:44	27-07-2021 08:09	0:00:00	0:00:00	0:00:00	60:25:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Sohna Road(GPTL)	24-07-2021 19:53	27-07-2021 08:05	0:00:00	0:00:00	0:00:00	60:12:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	29-07-2021 11:00	30-07-2021 01:27	0:00:00	0:00:00	0:00:00	14:27:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	-
-	-	-
-	-	-

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)			Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)		
NIL	-	-	-	-	-	-
-	-	-	-	-	-	-
Total						