

Name of Transmission Licensee :- Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of June 2021

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400/220kV 500 MVA ICT-2 at Sohna Road(GPTL)	28-06-2021 10:48	29-06-2021 18:37	31:49:00	0:00:00	0:00:00	0:00:00	GPTL Taken the shutdown for PRD-Replacement work.	99.79%
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	05-06-2021 22:37	11-06-2021 00:05	0:00:00	0:00:00	0:00:00	121:28:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Sohna Road(GPTL)	09-06-2021 23:20	10-06-2021 23:55	0:00:00	0:00:00	0:00:00	24:35:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Sohna Road(GPTL)	11-06-2021 21:49	13-06-2021 03:57	0:00:00	0:00:00	0:00:00	30:08:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	11-06-2021 21:53	01-07-2021 00:00	0:00:00	0:00:00	0:00:00	458:07:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	23-06-2021 12:36	01-07-2021 00:00	0:00:00	0:00:00	0:00:00	179:24:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month	
400kV D/C Sohna Road(GPTL) - Gurgaon(PG) Ckt-2	07-06-2021 10:40	07-06-2021 20:43	0:00:00	0:00:00	0:00:00	10:03:00	PGCIL Taken emergency shutdown for attend the critical hot spot in Y-phase wavetrap at Gurgaon S/S.	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of June 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	-
-	-	-
-	-	-

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of June 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)				Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)			
NIL	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-
Total							