

Name of Transmission Licensee :- Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of May 2021

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400/220kV 500 MVA ICT-1 at Sohna Road(GPTL)	11-05-2021 20:07	11-05-2021 23:20	3:13:00	0:00:00	0:00:00	0:00:00	Tripped due to OSR protection operated.	99.98%
400kV 125 MVAR Bus Reactor-1 at Kadarpur	27-05-2021 22:56	30-05-2021 17:16	0:00:00	0:00:00	0:00:00	66:20:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)				Compensation paid (in Rs)	
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)				
NIL	-	-	-	-				-
-	-	-	-	-				-
Total								