

Name of Transmission Licensee :- Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of September 2021

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min			
400/220kV 500 MVA ICT-1 at Kadarpur(GP	07-09-2021 14:05	07-09-2021 15:23	1:18:00	0:00:00	0:00:00	0:00:00	Emergency outage availed by Kadarpur (GPTL) for attending oil leakage from NIFPS system.	99.63%
400/220kV 500 MVA ICT-1 at Sohna Road(GP	13-09-2021 08:35	15-09-2021 13:59	53:24:00	0:00:00	0:00:00	0:00:00	Tripping due to SPR operated for ICT-1 at Sohna Road (GPTL). Clearance for Charging the ICT was given at 13:59, ICT resorted at 14:45.	
400kV 125 MVAR Bus Reactor-1 at Prithala	01-09-2021 00:00	04-09-2021 03:54	0:00:00	0:00:00	0:00:00	75:54:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV Aligarh - Prithala (GPTL) Ckt-1	01-09-2021 10:52	01-09-2021 18:33	0:00:00	0:00:00	0:00:00	7:41:00	Shutdown availed by Powergrid (Aligarh S/s) for AMP of line bay equipment at Aligarh end.	
400kV 125 MVAR Bus Reactor-1 at Prithala	06-09-2021 12:36	11-09-2021 07:37	0:00:00	0:00:00	0:00:00	115:01:00	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
400kV D/C Sohna Road(GPTL) - Manesar(P	09-09-2021 09:57	09-09-2021 15:50	0:00:00	0:00:00	0:00:00	5:53:00	Shutdown availed by Powergrid (Manesar GIS S/S) for Bay AMP work at Manesar GIS substation.	
400/220kV 500 MVA ICT-1 at Sohna Road(GP	15-09-2021 13:59	15-09-2021 14:45	0:00:00	0:00:00	0:00:00	0:46:00	Tripping due to SPR operated for ICT-1 at Sohna Road (GPTL). Clearance for Charging the ICT was given at 13:59, ICT resorted at 14:45.	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of September 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	-
-	-	-
-	-	-

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of September 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)			Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)		
NIL	-	-	-	-	-	-
-	-	-	-	-	-	-
Total						