

Name of Transmission licensee :- NRSSXXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of August 2021

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Am	01-08-2021 00:00	06-08-2021 00:04	0:00:00	0:00:00	0:00:00	120:04:00	Continuously in outage from Feb'21, Hand trip as per RLDC instruction due to voltage regulation.	100.00%
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Am	01-08-2021 00:00	01-09-2021 00:00	0:00:00	0:00:00	0:00:00	744:00:00	Continuously in outage from April'21, Hand trip as per RLDC instruction due to voltage regulation. Still not charged in this month	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Am	11-08-2021 11:31	01-09-2021 00:00	0:00:00	0:00:00	0:00:00	492:29:00	Hand trip as per RLDC instruction due to voltage regulation. Still not charged in this month	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of August 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)			Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)		
NIL	-	-	-	-		-
-	-	-	-	-		-
Total						