

Name of Transmission licensee :- NRSSXXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of July 2021

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400/220 kV, 315 MVA-1 ICT at Amargarh substation	13-07-2021 13:24	13-07-2021 14:01	0:37:00	0:00:00	0:00:00	0:00:00	Emergency shutdown was taken to arrest oil leakage issue in the oil drain valve of NIPPS in B-Phase. ICT B-phase has been changed with spare phase .	99.99%
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh SS.	01-07-2021 00:00	01-08-2021 00:00	0:00:00	0:00:00	0:00:00	744:00:00	Continuously in outage from Feb21, Hand trip as per RLDC instruction due to voltage regulation. Still not charged in this month	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh SS.	01-07-2021 00:00	01-08-2021 00:00	0:00:00	0:00:00	0:00:00	744:00:00	Continuously in outage from April21, Hand trip as per RLDC instruction due to voltage regulation. Still not charged in this month	

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2021

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2021

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)			Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)		
NIL	-	-	-	-		-
-	-	-	-	-		-
Total						