I. AC Transmission Line Outage Details for the month of May 2021

Schedule I

	Outage	Restoration	Duration of Outage Attributable to					
Element Name	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available	Reason of Outage	% Availability
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Sambha-Amargarh Ckt-1	16-05-2021 13:36	16-05-2021 16:45	3:09:00	0:00:00	0:00:00	0:00:00	Taken emergency outage for removing foreign material from the line.	
400kV Sambha-Amargarh Ckt-1	20-05-2021 21:01	20-05-2021 22:21	1:20:00	0:00:00	0:00:00	0:00:00	Line tripped on R- phase to B-phase Fault.	
400kV Sambha-Amargarh Ckt-1	23-05-2021 19:54	23-05-2021 21:28	1:34:00	0:00:00	0:00:00	0:00:00	Line tripped due to PRV-2 operated at Line Reactor at Amargarh Substation.	
400/220 kV, 315 MVA-2	25-05-2021 15:04	25-05-2021 17:51	2:47:00		0:00:00	0:00:00	Emergency Shutdown has been taken for oil leakage rectification work.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Am	01-05-2021 00:00	01-06-2021 00:00	0:00:00	0:00:00	0:00:00	744:00:00	Continuously in outage from Feb21, Hand trip as per RLDC instruction due to voltage regulation. Still not charged in this month	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Am	01-05-2021 00:00	01-06-2021 00:00	0:00:00	0:00:00	0:00:00	744:00:00	Continuously in outage from April21, Hand trip as per RLDC instruction due to voltage regulation. Still not charged in this month	99.79%
400 kV Jalandhar (PG)-Samba (PG)-II	07-05-2021 03:31	07-05-2021 07:37	0:00:00	0:00:00	0:00:00	4:06:00	PGCIL taken the shutdown for checking of Y-phase voltage discrepancy at samba substation. Only Line portion belong to NRSS.	
400kV Amargarh (NRSS)-Wagoora(PG)-2	17-05-2021 11:33	17-05-2021 12:12	0:00:00	0:00:00	0:00:00	0:39:00	PGCIL taken the emergency shutdown due to heavy sparking at Bus- Isolator (406-89B) at Wagoora end (hand tripped) and DT received at Amargarh end	
400kV Uri1(NHPC)-Amargarh(NRSS)-1	27-05-2021 11:50	27-05-2021 13:30	0:00:00		0:00:00	1:40:00	PGCIL taken the emergency shutdown for tree cutting work for the line portion section belongs to	

Schedule II

$II.\ Elements\ where\ restoration\ time\ has\ exceeded\ the\ standards\ specified\ in\ Regulation\ 5\ (b)\ for\ the\ month\ of\ May\ 2021$

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of May $2021\,$

Element Name	Violation of Regulation 5(a)		Violation of Regu		gulation 5(b)			
	% Availability prescribed	Actual % Availability	Restoration time		Actual restoration		Compensation paid (in Rs)	
			prescribed		time			
			(in days)		(in days)			
NIL	-	-	-	-				-
-	-	-	-	-				-
Total								