I. AC Transmission Line Outage Details for the month of June 2021

Schedule I

	Outage	Restoration	Duration of Outage Attributable to					
Element Name	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available	Reason of Outage	% Availability
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV Banala Nalagarh	04/06/2021 09:54	04/06/2021 18:12	00:00	08:18	00:00	08:18	For Bay AMP work at Nallagarh substation. Shutdown availed by CPCC-02.	
400 kV Parbati III-Banala Pooling Station	22/06/2021 11:10	22/06/2021 14:17	00:00	03:07	00:00	03:07	For changing Link Box of XLPE cable of Parbat3-Banala Transmission line. To avoid tripping as Cable temp. is high. S/D taken by Parbati- 3(NHPC).	100.00%

Schedule II

$II.\ Elements\ where\ restoration\ time\ has\ exceeded\ the\ standards\ specified\ in\ Regulation\ 5\ (b)\ for\ the\ month\ of\ June\ 2021$

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of June 2021 $\,$

Element Name	Violation of R	Violation of Regulation 5(a) Violation of I			Regulation 5(b)			
	%	Actual % Availability	Restoration time		Actual restoration		Compensation paid (in Rs)	
	Availability prescribed		prescribed (in days)		time (in days)			
NIL	-	-	-	-				-
-	-	-	-	-				-
	Total							