

Name of Transmission Licensee :- Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of August 2021

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400KV Patiala-Patran-1	04/08/2021 18:16	04/08/2021 21:01	02:45	00:00	00:00	00:00	Emergency shutdown taken by PTCL for R-Phase bushing side compartment BD7 SF6 gas refilling.  185th OCC Approved Shutdown availed by PTCL for SF6 Leakage arresting.	98%
400/220 KV ICT-1 at Patran	26/08/2021 09:35	29/08/2021 19:19	81:44	00:00	00:00	00:00		

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of August 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)				Compensation paid (in Rs)	
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)		Actual restoration time (in days)			
NIL	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-
<b>Total</b>								