

Name of Transmission Licensee :- Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of May 2021

Schedule I

Element Name	Outage Date Time	Restoration Date Time	Duration of Outage Attributable to				Reason of Outage	% Availability
			Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400/220 KV ICT-1 at Patran	25-05-2021 14:43	25-05-2021 17:41	2:58:00	0:00:00	0:00:00	0:00:00	99.93%	
400KV Patiala-Patran-2	31-05-2021 20:41	31-05-2021 21:30	0:00:00	0:49:00	0:00:00	0:00:00		
400KV Kaithal -Patran-2	31-05-2021 21:11	31-05-2021 22:35	0:00:00	1:24:00	0:00:00	0:00:00		

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	-	
-	-	
-	-	

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)				Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)			
NIL	-	-	-	-			-
-	-	-	-	-			-
Total							