

Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of August 2021

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date	Time	Date	Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
					Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
765 KV Bus Reactor at BDTCL Dhule	01-08-2021	00:00:00	01-08-2021	04:21:00	0:00	0:00	0:00	4:21	Continuous in outage from previous month, Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	99.97%
765 KV Bus Reactor at BDTCL Dhule	05-08-2021	06:24:00	09-08-2021	17:32:00	0:00	0:00	0:00	107:08	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	07-08-2021	09:05:00	08-08-2021	16:58:00	0:00	0:00	0:00	31:53	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	09-08-2021	09:40:00	13-08-2021	17:27:00	0:00	0:00	0:00	103:47	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	10-08-2021	07:01:00	10-08-2021	19:06:00	0:00	0:00	0:00	12:05	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	12-08-2021	05:51:00	13-08-2021	22:23:00	0:00	0:00	0:00	40:32	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	14-08-2021	08:42:00	14-08-2021	18:08:00	0:00	0:00	0:00	9:26	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	16-08-2021	06:22:00	16-08-2021	18:21:00	0:00	0:00	0:00	11:59	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	16-08-2021	08:43:00	17-08-2021	23:05:00	0:00	0:00	0:00	38:22	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	17-08-2021	08:22:00	17-08-2021	20:30:00	0:00	0:00	0:00	12:08	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	20-08-2021	06:53:00	20-08-2021	10:31:00	0:00	0:00	0:00	3:38	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	21-08-2021	06:59:00	21-08-2021	21:38:00	0:00	0:00	0:00	14:39	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	23-08-2021	10:39:00	24-08-2021	20:14:00	0:00	0:00	0:00	33:35	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	25-08-2021	11:52:00	25-08-2021	17:48:00	0:00	0:00	0:00	5:56	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Vadodara Line Reactor at BDTCL	26-08-2021	19:14:00	26-08-2021	22:54:00	3:40	0:00	0:00	0:00	Line Reactor Tripped due to PD-operated in B-phase at Dhule substation, maloperation of relay.	
765 KV Bus Reactor at BDTCL Dhule	27-08-2021	05:22:00	31-08-2021	00:07:00	0:00	0:00	0:00	90:45	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 kv bus reactor at BDTCL Bhopal	30-08-2021	09:05:00	30-08-2021	20:15:00	0:00	0:00	0:00	11:10	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	
765 KV Bus Reactor at BDTCL Dhule	31-08-2021	11:27:00	31-08-2021	13:28:00	0:00	0:00	0:00	2:01	Bus reactor hand tripped as per RLDC instruction due to voltage regulation.	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of August 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
			Total		Nil