Bhopal Dhule Transmission Company Limited

I. AC Transmission Line Outage Details for the month of September 2021 $\,$

redr	

	Ou	tage	Resto	ration	Duration of Outage Attributable to		Reason of	%		
Element Name	Date	Time	Date	Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available	Outage	Availability
					Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
765 KV Bus Reactor at BDTCL Dhule	04-09-2021	06:08:00	07-09-2021	20:47:00	0:00	0:00	0:00	86:39	Bus reactor hand tripped as per RLDC instruction due to voltage regulation	
765 kv bus reactor at BDTCL Bhopal	06-09-2021	08:31:00	06-09-2021	18:29:00	0:00	0:00	0:00	9:58	Bus reactor hand tripped as per RLDC instruction due to voltage regulation	
765 KV Bus Reactor at BDTCL Dhule	08-09-2021	08:05:00	11-09-2021	13:58:00	0:00	0:00	0:00	77:53	Bus reactor hand tripped as per RLDC instruction due to voltage regulation	
765 kv bus reactor at BDTCL Bhopal	11-09-2021	06:48:00	12-09-2021	00:22:00	0:00	0:00	0:00	17:34	Bus reactor hand tripped as per RLDC instruction due to voltage regulation	
765 KV Bus Reactor at BDTCL Dhule	15-09-2021	09:25:00	19-09-2021	18:32:00	0:00	0:00	0:00	105:07	Bus reactor hand tripped as per RLDC instruction due to voltage regulation	
400 kV Bhopal(BDTCL) -Bhopal(MPPTCL)	22-09-2021	11:04:00	22-09-2021	18:02:00	0:00	0:00	0:00	6:58	BAY EQUIPMENT MAINTENANCE AND TESTING WORK at Bhopal-MPPTCL substation. Shutdown availed by SLDC- MP.	100%
765 KV Bus Reactor at BDTCL Dhule	23-09-2021	07:30:00	26-09-2021	20:03:00	0:00	0:00	0:00	84:33	Bus reactor hand tripped as per RLDC instruction due to voltage regulation	
765 kv bus reactor at BDTCL Bhopal	24-09-2021	06:47:00	25-09-2021	20:45:00	0:00	0:00	0:00	37:58	Bus reactor hand tripped as per RLDC instruction due to voltage regulation	
765 KV Bus Reactor at BDTCL Dhule	27-09-2021	07:12:00	29-09-2021	01:33:00	0:00	0:00	0:00	42:21	Bus reactor hand tripped as per RLDC instruction due to voltage regulation	
765KV S/C Aurangabad-Dhule Line	28-09-2021	06:19:00	28-09-2021	06:19:00	0:00	0:00	0:00	0:00	Line A/R successful due to Transient R- phase to Earth Fault.	
<u> </u>	-	-	-							

Schedule II

Schedule III

$II.\ Elements\ where\ restoration\ time\ has\ exceeded\ the\ standards\ specified\ in\ Regulation\ 5\ (b)\ for\ the\ month\ of\ September\ 2021$

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

$III.\ Details\ of\ compensation\ paid\ by\ the\ inter-State\ transmission\ licensee\ for\ the\ month\ of\ September\ 2021$

Element Name	Violation of F	Regulation 5(a)	Violati	ion of Regulation 5(b)	
	%	Actual %	Restoration time	Actual restoration	Compensation paid (in Rs)
	Availability prescribed	Availability	prescribed	time	Compensation part (in 163)
			(in days)	(in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
	Nil				