

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	%
	Date	Time	Date	Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
765kV JTCL Dharamjaygarh-Jabalpur CKT-4	01-05-2021	00:00:00	01-06-2021	00:00:00	0:00	0:00	0:00	744:00	Continuous under outage since last month due to voltage regulation as per RLDC instruction. Still not charged	99.67%
765kV Jabalpur-Bina III	08-05-2021	10:51:00	08-05-2021	14:25:00	0:00	0:00	3:34	0:00	Line A/T on B phase to E/F due to fire in wheat waste field burnt by the farmer between location no.109/S-108/6 which causes huge smoke led to tripping of the line. Attached here with the Photograph for your reference.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	08-05-2021	17:20:00	08-05-2021	17:20:00	0:00	0:00	0:00	0:00	A/R successful due to R-Phase to earth fault.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	09-05-2021	17:04:00	09-05-2021	19:54:00	0:00	0:00	2:50	0:00	Line tripped on V-Phase to B-Phase fault due to inclement weather condition foreign material (Tarpaulin/Polyester canopy) came in contact with the line which led to transient Pb-Pb tripping. Attached patrolling report, photograph and newspaper cutting of inclement weather condition for reference. Clearance for charging the line was provided at 19:54 hrs, but as per RLDC instruction the line Tripping was converted into voltage regulation at 22:02 hrs. outage. Email copy attached for your reference	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	09-05-2021	19:54:00	09-05-2021	22:02:00	0:00	0:00	0:00	2:08	Line charging clearance was provided at 19:54 hrs, but as per RLDC instruction the tripping was converted into voltage regulation at 22:02 hrs. outage. Email copy attached for your reference	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	09-05-2021	22:02:00	10-05-2021	07:20:00	0:00	0:00	0:00	0:18	Hand tripped due to voltage regulation as per RLDC instruction	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	11-05-2021	22:23:00	11-05-2021	22:23:00	0:00	0:00	0:00	0:00	A/R successful due to V-Phase to earth fault.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	13-05-2021	16:59:00	13-05-2021	18:35:00	0:00	0:00	1:36	0:00	Line tripped on B-phase to Earth fault due to frequent lightning and photograph of copper bond burnt attached for your reference, also attached here with the patrolling report and news paper cutting of inclement weather condition.	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	13-05-2021	18:35:00	13-05-2021	19:56:00	0:00	0:00	0:00	1:21	JTCL given the charging clearance at 18:35 Hrs & the WELDC code for charging was issued at 18:39 Hrs. The delay in line charging was due to heavy rainfall at the site as conveyed by RTAMC. Email copy attached for your reference	
765kV JTCL Dharamjaygarh-Jabalpur CKT-3	16-05-2021	14:01:00	16-05-2021	14:01:00	0:00	0:00	0:00	0:00	A/R successful due to B-Phase to earth fault.	
765kV Jabalpur-Bina III	17-05-2021	17:54:00	17-05-2021	17:54:00	0:00	0:00	0:00	0:00	A/R successful due to B-Phase to earth fault.	
765kV Jabalpur-Bina III	17-05-2021	18:36:00	17-05-2021	18:36:00	0:00	0:00	0:00	0:00	A/R successful due to B-Phase to earth fault.	

Schedule II

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2021

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

Schedule III

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2021

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil