

Dhule Power Transmission Limited

REGISTERED OFFICE: CORE-4, SCOPE COMPLEX, 7 LODHI ROAD, DELHI -110003

CIN NO.: U42202DL20203GOI415484

NOTICE

UNDER SUB-SECTION (2) OF SECTION 15 OF THE ELECTRICITY ACT, 2003

1. Dhule Power Transmission Limited, having its registered office at Core-4, Scope Complex, 7 Lodhi Road, Delhi -110003 which is incorporated under the Companies Act, 2013 has made up an application before the Central Electricity Regulatory Commission, New Delhi under Sections 14, 15, 79(1)(e) of the Electricity Act, 2003 read with Central Electricity Regulatory Commission (Procedure, Terms and Conditions for Grant of Transmission License and other related matters) Regulations, 2009 seeking Transmission License for Dhule Power Transmission Ltd. for the Transmission Project being implemented through Tariff Based Competitive Bidding Process, the details of which are given :

Sl. No.	Name of the line/ substation (location)(Scope of Transmission Scheme)	Line Length/Capacity (Capacity/km)	Levelized Transmission Charges	Commissioning Schedule	Remarks
1	Establishment of 4x500 MVA, 400/220 kV Pooling Station near Dhule along with 2x125 MVA (420 kV) Bus Reactors.	<ul style="list-style-type: none">• 400/220 kV, 500 MVA ICT – 4 Nos.• 400 kV ICT bays – 4 Nos.• 220 kV ICT bays – 4 Nos. (2 Nos. on 220 kV bus section 1 and 2 Nos. on 220 kV bus section 2)• 400 kV line bays – 2 Nos.• 125 MVA, 420 kV Bus reactor – 2 Nos.• Bus reactor bay: 2 Nos.• 220 kV Bus coupler bay- 2 Nos.• Transfer Bus Coupler (TBC) bay - 2 Nos.• 220 kV line bays – 7 Nos. (for RE interconnection out of which 4 Nos. would be on 220 kV bus section 1 and 3 Nos. on 220 kV bus section 2)• 220 kV Bus Sectionalizer- 1 set Future provision Space for <ul style="list-style-type: none">• 400 kV line bays along with switchable line reactor – 8 Nos.• 400/220 kV ICT along with bays -6 Nos.• 400 kV Bus Reactor along with bays: 2 Nos.• 400 kV Bus Sectionalization bay: 1- set• 220 kV line bays: 9 Nos.• 220 kV Sectionalization bay: 1 set• 220 kV BC and TBC: 1 Nos.	INR 528.27 million per annum,	08.02.2026	-
2	Dhule PS – Dhule (BDTCL) 400 kV D/c line (Quad ACSR/AAAC/AL59 Moose equivalent)				
3	2 Nos. 400 kV line bays at Dhule (BDTCL) for Dhule PS – Dhule (BDTCL) 400 kV D/c Line 400 kV Line bays – 2 Nos.				

2. Complete application and other documents filed before the commission are available on the website <https://www.indigrid.co.in/documents-manager/> for access of any person. The application can also be inspected at the office of the company at 10th Floor, Berger Delhi One, Sector 16B Noida, Uttar Pradesh-201301 with Mr. Lokendra Singh Ranawat or Office of the commission in accordance with the procedure specified by the commission.

3. Objections and suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 3rd and 4th Floor, Chandarlok Bhawan, 36, Janpath, New Delhi-110001, with a copy to the applicant at the address of its corporate office within 30 days of publication of this notice in the newspaper.

Place: Noida

Date: 29.02.2024

Sd/-
Amitanshu Srivastava
Director