

East North Interconnection Company Limited

I. AC Transmission Line Outage Details for the month of JAN 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 1(ALIP- SLG #1)	05-01-2024 08:24	05-01-2024 22:15	0:00:00	0:00:00	0:00:00	13:51:00	PGCIL ER-2 taken the shutdown for LBB Relay retrofitting at Binaguri end. Only Line portion belongs to ENICL.	100.00%
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 2(ALIP- SLG #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-2(NPRN- BSF# 2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 1(BNG- ALIP #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 2(BNG- ALIP #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	

East North Interconnection Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JAN 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of JAN 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time Prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil