

East North Interconnection Company Limited

I. AC Transmission Line Outage Details for the month of JUN 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)	17-06-2023	17-06-2023	0:00:00	0:00:00	0:00:00	8:03:00	PGCIL taken the shutdown for Line Bay AMP Work. Only line portion belongs to ENICL.	99.481%
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-2 (NPRN-BSF# 2)	21-06-2023	21-06-2023	14:30:00	0:00:00	0:00:00	0:00:00	Line trip on Y-phase to B-phase fault due to conductor snapping. Charging clearance was given at 19:12Hrs and charging code for the same was received at 19:17Hrs and line was finally charged at 21:05Hrs. Delay in charging was due to unknown reason at both end substation, email communication enclosed here with for your reference. only line portion belongs to ENICL.	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-2 (NPRN-BSF# 2)	21-06-2023	21-06-2023	0:00:00	1:48:00	0:00:00	0:00:00	Charging clearance was given at 19:12Hrs and charging code for the same was received at 19:17Hrs and line was finally charged at 21:05Hrs. Delay in charging was due to unknown reason at both end substation, email communication enclosed here with for your reference. only line portion belongs to ENICL.	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 1(BNG- ALIP #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 2(BNG- ALIP #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 1(ALIP- SLG #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 2(ALIP- SLG #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	

East North Interconnection Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JUN 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of JUN 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time Prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil