

East North Interconnection Company Limited

I. AC Transmission Line Outage Details for the month of NOV 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)	12-11-2023 00:50	13-11-2023 14:58	38:08:00	0:00:00	0:00:00	0:00:00	Due to Y Phase to B Phase fault. Tripping converted into Emergency S/D. Charging clearance was given at 14:58Hrs and Charging code was received at 15:15Hrs and line was finally charged at 16:06Hrs. Delay in charging was beyond the control of ENICL. Please consider the additional outage period under Others account. Only Line portion belongs to ENICL. Enclosed here with the email copy for reference.	98.34%
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-1 (NPRN-BSF#1)	13-11-2023 14:58	13-11-2023 16:06	0:00:00	1:08:00	0:00:00	0:00:00	Charging clearance was given at 14:58Hrs and Charging code was received at 15:15Hrs and line was finally charged at 16:06Hrs. Delay in charging was beyond the control of ENICL. Please consider the additional outage period under Others account. Only Line portion belongs to ENICL. Enclosed here with the email copy for reference.	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-2 (NPRN-BSF# 2)	15-11-2023 08:42	15-11-2023 16:57	8:15:00	0:00:00	0:00:00	0:00:00	ENICL taken the shutdown availed for mid span joint replacement work. Charging clearance was given at 16:57Hrs and Charging code was received at 17:01Hrs and line was finally charged at 18:22Hrs. Delay in charging was beyond the control of ENICL. Please consider the additional outage period under Others account. Only Line portion belongs to ENICL. Enclosed here with the email copy for reference.	
400 kv (Quad) D/C Purnia-Biharshrif Line CKT-2 (NPRN-BSF# 2)	15-11-2023 16:57	15-11-2023 18:22	0:00:00	1:25:00	0:00:00	0:00:00	Charging clearance was given at 16:57Hrs and Charging code was received at 17:01Hrs and line was finally charged at 18:22Hrs. Delay in charging was beyond the control of ENICL. Please consider the additional outage period under Others account. Only Line portion belongs to ENICL. Enclosed here with the email copy for reference.	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 1(BNG- ALIP #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Bongaigaon - Alipurduar line CKT- 2(BNG- ALIP #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 1(ALIP- SLG #1)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	
400 kv (Quad) D/C Alipurduar - Siliguri line CKT- 2(ALIP- SLG #2)			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outages in this line	

East North Interconnection Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of NOV 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of NOV 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time Prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil