

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of APR 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1	23-04-2023	01-05-2023	0:00	0:00	0:00	180:51	Line hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month.	100.000%
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1			0:00	0:00	0:00	0:00	NO Tripping / Outage in this month	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-2			0:00	0:00	0:00	0:00	NO Tripping / Outage in this month	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2			0:00	0:00	0:00	0:00	NO Tripping / Outage in this month	

Odisha Generation Phase-II Transmission Limited**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of APR 2023****Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

Sl. No.

Voltage Level Name of Line COD

Line Length (No.of sub cor Weightage Factor

(N:

III. Details of compensation paid by the inter-State transmission licensee for the month of APR 2023**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil