

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of JUL 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1	01-07-2023	06-07-2023	0:00	0:00	0:00	124:01	Continuously in outage from June-23, Line hand tripped as per RLDC instruction due to voltage regulation.	100.000%
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	06-07-2023	06-07-2023	0:00	0:00	2:08	0:00	Line Tripped on transient fault due to inclement weather condition & lightning enclosed here with the newspaper cutting & IMD report for your reference which indicate about the inclement weather condition & email communication for your reference. Charging clearance was given at 03:29Hrs and Charging code was received at 04:13Hrs and delay in Charging was due to unknown reason and line was finally charged at 04:43Hrs.	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	06-07-2023	06-07-2023	0:00	0:30	0:00	0:00	Charging clearance was given at 03:29Hrs and Charging code was received at 04:13Hrs and delay in charging was due to unknown reason and line was finally charged at 04:43Hrs. Enclosed here with the email communication for your reference.	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	23-07-2023	01-08-2023	0:00	0:00	0:00	200:12	Line hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month.	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1			0:00	0:00	0:00	0:00	No Tripping / Outage in the month of JUL23	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-2			0:00	0:00	0:00	0:00	No Tripping / Outage in the month of JUL23	

