

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of MAY 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1	01-05-2023	01-06-2023	0:00	0:00	0:00	744:00	Continuously in outage from previous month, Line hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month.	100.000%
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1			0:00	0:00	0:00	0:00	NO Tripping / Outage in this month	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-2			0:00	0:00	0:00	0:00	NO Tripping / Outage in this month	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2			0:00	0:00	0:00	0:00	NO Tripping / Outage in this month	

