

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of NOV 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1	01-11-2023 00:00	22-11-2023 14:25	0:00:00	0:00:00	0:00:00	518:25:00	Continuously in outage since September 2023. Line hand tripped as per RLDC instruction due to voltage regulation.	100.000%
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1	25-11-2023 08:21	30-11-2023 16:31	0:00:00	0:00:00	0:00:00	128:10:00	OGPTL taken the shutdown for diversion related work due to PWD road project.	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-2	25-11-2023 08:23	30-11-2023 16:33	0:00:00	0:00:00	0:00:00	128:10:00	OGPTL taken the shutdown for diversion related work due to PWD road project.	
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2			0:00:00	0:00:00	0:00:00	0:00:00	No Tripping / Outage in this month	

Odisha Generation Phase-II Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of NOV 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

Sl. No. Voltage Level Name of Line COD Line Length (No.of sub cor Weightage Factor (N:

III. Details of compensation paid by the inter-State transmission licensee for the month of NOV 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil