

Odisha Generation Phase-II Transmission Limited

I. AC Transmission Line Outage Details for the month of SEP 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-2	01-09-2023 00:00	20-09-2023 01:27	0:00	0:00	0:00	457:27	Continuously in outage from July-23, Line hand tripped as per RLDC instruction due to voltage regulation.	100.000%
765kV D/C Jharsuguda(Sundargarh)-Raipur pool CKT-1	23-09-2023 02:08	30-09-2023 00:00	0:00	0:00	0:00	165:52	Line hand tripped as per RLDC instruction due to voltage regulation. Still not charged in this month.	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-1			0:00	0:00	0:00	0:00	No Tripping / Outage in the month of SEP23	
400kV D/C IB-OPGC-Jharsuguda(Sundargarh) Ckt-2			0:00	0:00	0:00	0:00	No Tripping / Outage in the month of SEP23	

