

Purulia & Kharagpur Transmission Company Limited

I. AC Transmission Line Outage Details for the month of APR 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	01-04-2023	01-04-2023	0:00	0:00	0:00	9:51	Continuously in outage from previous month, Line Hand Tripped as per RLDC instruction due to Voltage regulation.	100.000%
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	02-04-2023	02-04-2023	0:00	0:00	0:00	9:50	Line Hand Tripped as per RLDC instruction due to Voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	03-04-2023	03-04-2023	0:00	0:00	0:00	8:57	Line Hand Tripped as per RLDC instruction due to Voltage regulation.	
400 kV Chaibasa-Kharagpur D/C line CKT- 2	03-04-2023	03-04-2023	0:00	0:00	0:00	3:37	PGCIL taken the shutdown for modification of PRV Tripping at Chaibasa end. Only Line Portion Belongs to PKTCL	
400 kV Chaibasa-Kharagpur D/C line CKT- 1			0:00	0:00	0:00	0:00	NO Tripping / Outage in this month	

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of APR 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of APR 2023

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil