

Purulia & Kharagpur Transmission Company Limited
I. AC Transmission Line Outage Details for the month of DEC 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	03-12-2023 00:49	03-12-2023 09:20	0:00:00	0:00:00	0:00:00	8:31:00	Line hand tripped as per RLDC instruction due to voltage regulation.	100.000%
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	04-12-2023 00:28	04-12-2023 08:04	0:00:00	0:00:00	0:00:00	7:36:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	04-12-2023 08:04	04-12-2023 18:12	0:00:00	0:00:00	0:00:00	10:08:00	WBSETCL taken the Shutdown for replacement of density monitor at zone-9 by SIEMENS at New PPSP Sub-station. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	05-12-2023 00:13	05-12-2023 17:09	0:00:00	0:00:00	0:00:00	16:56:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	05-12-2023 22:47	06-12-2023 17:04	0:00:00	0:00:00	0:00:00	18:17:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	06-12-2023 21:49	07-12-2023 08:05	0:00:00	0:00:00	0:00:00	10:16:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	07-12-2023 08:05	07-12-2023 19:35	0:00:00	0:00:00	0:00:00	11:30:00	WBSETCL taken the Shutdown for replacement of density monitor at zone-9 by SIEMENS at New PPSP Sub-station. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	07-12-2023 22:38	08-12-2023 07:50	0:00:00	0:00:00	0:00:00	9:12:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	08-12-2023 07:50	08-12-2023 19:11	0:00:00	0:00:00	0:00:00	11:21:00	WBSETCL taken the Shutdown for replacement of density monitor at zone-9 by SIEMENS at New PPSP Sub-station. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	08-12-2023 23:03	11-12-2023 11:39	0:00:00	0:00:00	0:00:00	60:36:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	19-12-2023 17:21	19-12-2023 20:53	0:00:00	0:00:00	0:00:00	3:32:00	Shutdown availed by PPSP for SF6 gas filling work at NEW PPSP. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	19-12-2023 20:53	20-12-2023 11:57	0:00:00	0:00:00	0:00:00	15:04:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	20-12-2023 22:34	21-12-2023 08:45	0:00:00	0:00:00	0:00:00	10:11:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 kV Chaibasa-Kharagpur D/C line CKT- 1	22-12-2023 07:59	22-12-2023 19:25	0:00:00	0:00:00	0:00:00	11:26:00	Shutdown availed by WBSETCL for maintenance work at Kharagpur end. Only line portion belongs to PKTCL.	
400 kV Chaibasa-Kharagpur D/C line CKT- 2			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outage in this month	

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of DEC 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of DEC 2023

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil