

Purulia & Kharagpur Transmission Company Limited
I. AC Transmission Line Outage Details for the month of JUL 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kV Chaibasa-Kharagpur D/C line CKT- 1	07-07-2023	07-07-2023	0:00	1:16	0:00	0:00	PKTCL taken the emergency shutdown for insulator replacement work at Loc no 66B/0 (Tower No-417). Shutdown was taken at 09:16Hrs and due to unknown reason at both end substation issuance of getting the PTW was delayed and PTW was finally issued at 10:32Hrs, enclosed here with the email communication. Please consider this period under other category, Only Line portion belong to PKTCL this is period is beyond the control of PKTCL.	99.794%
400 kV Chaibasa-Kharagpur D/C line CKT- 1	07-07-2023	07-07-2023	5:12	0:00	0:00	0:00	PKTCL taken the emergency shutdown for For insulator replacement work at Loc no 66B/0 (Tower No-417). Charging clearance was given at 15:42Hrs and charging code was received at 15:44Hrs, delayed in charging due to Kharagpur substation & RTAMC-Patna were not communicating with each other and line was finally charged at 17:02Hrs. Enclosed here with the email communication. Please consider the delayed period under other account as only line portion belongs to PKTCL.	
400 kV Chaibasa-Kharagpur D/C line CKT- 1	07-07-2023	07-07-2023	0:00	1:18	0:00	0:00	Charging clearance was given at 15:42Hrs and charging code was received at 15:44Hrs, delayed in charging due to Kharagpur substation & RTAMC-Patna were not communicating with each other and line was finally charged at 17:02Hrs. Enclosed here with the email communication. Please consider the delayed period under other account as only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	31-07-2023	31-07-2023	0:00	0:00	0:00	1:59	WBSETCL taken the shutdown for replacement of energy meter. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1			0:00	0:00	0:00	0:00	NO Tripping/outages in this month.	
400 kV Chaibasa-Kharagpur D/C line CKT- 2			0:00	0:00	0:00	0:00	NO Tripping/outages in this month.	

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JUL 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of JUL 2023

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil