

Purulia & Kharagpur Transmission Company Limited
I. AC Transmission Line Outage Details for the month of JUN 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kV Chaibasa-Kharagpur D/C line CKT- 1	17-06-2023	18-06-2023	14:11	0:00	0:00	0:00	Line tripped on R-phase to Earth fault due to insulator failure. Charging clearance was given on 18.06.2023 at 12:51Hrs and charging code for the same was received at 13:03Hrs. Delayed in charging was due to unknown reason and line was finally charged at 14:26Hrs. Enclosed here with the email communication for reference. Only Line portion belongs to PKTCL.	99.206%
400 kV Chaibasa-Kharagpur D/C line CKT- 1	18-06-2023	18-06-2023	0:00	1:23	0:00	0:00	Charging clearance was given on 18.06.2023 at 12:51Hrs and charging code for the same was received at 13:03Hrs. Delayed in charging was due to unknown reason and line was finally charged at 14:26Hrs. Enclosed here with the email communication for reference. Only Line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	26-06-2023	26-06-2023	3:38	0:00	0:00	0:00	PKTCL taken the emergency shutdown for damaged insulator rectification work. Shutdown was taken at 07:05Hrs and PTW was issued at 08:25Hrs delayed in issuance of PTW was due to unknown reason. Charging clearance was given at 10:34Hrs and charging code was received at 10:43Hrs and delay in charging was due to unknown reason and line was finally charged at 11:49Hrs.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	26-06-2023	26-06-2023	0:00	1:06	0:00	0:00	Charging clearance was given at 10:34Hrs and charging code was received at 10:43Hrs and delay in charging was due to unknown reason and line was finally charged at 11:49Hrs. Enclosed here with the email communication for reference.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	26-06-2023	26-06-2023	3:50	0:00	0:00	0:00	PKTCL taken the emergency shutdown for damaged insulator rectification work. Charging clearance was given at 17:24Hrs and charging code was received at 17:33Hrs and delay in charging was due to unknown reason and line was finally charged at 18:16Hrs.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	26-06-2023	26-06-2023	0:00	0:43	0:00	0:00	Charging clearance was given at 17:24Hrs and charging code was received at 17:33Hrs and delay in charging was due to unknown reason and line was finally charged at 18:16Hrs. Enclosed here with the email communication for reference.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1			0:00	0:00	0:00	0:00	NO Tripping/outages in JUN23.	
400 kV Chaibasa-Kharagpur D/C line CKT- 2			0:00	0:00	0:00	0:00	NO Tripping/outages in JUN23.	

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of JUN 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of JUN 2023

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil