Purulia & Kharagpur Transmission Company Limited I. AC Transmission Line Outage Details for the month of MAY 2023

redii	

	Outage	Restoration	Duration of Outage Attributable to		Reason of	%		
Element Name	Date & Time	Date & Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available	Outage	Availability
400 kV Chaibasa-Kharagpur D/C line CKT- 1	15-05-2023	15-05-2023	Hrs:Min 0:00	Hrs:Min 0:00	Hrs:Min	Hrs:Min 0:00	Line Tripped on transient fault due to inclement weather condition enclosed here with the newspaper cutting for your reference.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	26-05-2023	26-05-2023	0:00	3:20	0:00	0:00	Line Tripped on transient fault due to inclement weather condition enclosed here with the photograph and newspaper cutting for your reference.  Line tripped at 12:32Hrs and information regarding the same was received from ERLDC at 15:52Hrs, Request to kindly pls considered the outage period under others account because tripping information was not shared / available with PKCTL, this is beyond the control of licensee.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	26-05-2023	26-05-2023	0:00	3:20	0:00	0:00	Line Tripped on transient fault due to inclement weather condition enclosed here with the photograph and newspaper cutting for your reference. Line tripped at 12:32Hrs and information regarding the same was received from ERLDC at 15:52Hrs, Request to kindly pls considered the outage period under others account because tripping information was not shared / available with PKCTL, this is beyond the control of licensee.	100.000%
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	26-05-2023	26-05-2023	0:00	0:00	1:58	0:00	Line Tripped on transient fault due to inclement weather condition enclosed here with the newspaper cutting & email communication for your reference.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	26-05-2023	26-05-2023	0:00	0:00	0:41	0:00	Line Tripped on transient fault due to inclement weather condition enclosed here with the newspaper cutting & email communication for your reference.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	31-05-2023	31-05-2023	0:00	0:55	0:00	0:00	Line Tripped due to DT received at New Ranchi SS from New PPSP SS.  No fault in the line, only line portion belongs to PKTCL.  Tripped due to Relay / PLCC maloperation.  Enclosed here with the DR for reference and record purpose.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	31-05-2023	31-05-2023	0:00	0:32	0:00		Line Tripped due to DT received at New Ranchi SS from New PPSP SS.  No fault in the line, only line portion belongs to PKTCL.  Tripped due to Relay / PLCC maloperation.  Enclosed here with the DR for reference and record purpose.	
400 kV Chaibasa-Kharagpur D/C line CKT- 2			0:00	0:00	0:00	0:00	NO Tripping / Outage in May-23	

# Purulia & Kharagpur Transmission Company Limited

# II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of MAY 2023

	Restoration time as specified in	Actual restoration time	
Element Name	Regulation 5 (b)	(in days)	
	(in days)		
Nil	Nil	Nil	
Nil	Nil	Nil	
Nil	Nil	Nil	

# III. Details of compensation paid by the inter-State transmission licensee for the month of MAY 2023

# Schedule III

Element Name	Violation of R	egulation 5(a)	tion 5(a) Violation of Regulation 5(b)		
	%		Restoration time	Actual restoration	
	Availability prescribed		prescribed	time	Compensation paid (in Rs)
	•	-	(in days)	(in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil