

Purulia & Kharagpur Transmission Company Limited
I. AC Transmission Line Outage Details for the month of NOV 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kV Chaibasa-Kharagpur D/C line CKT- 2	22-11-2023 12:03	22-11-2023 16:25	0:00:00	0:00:00	0:00:00	4:22:00	PGCIL taken the emergency shutdown for hotspot rectification work at Chaibasa end. Only Line portion belong PKTCL.	100.000%
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	25-11-2023 22:47	26-11-2023 18:35	0:00:00	0:00:00	0:00:00	19:48:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	26-11-2023 23:05	28-11-2023 10:42	0:00:00	0:00:00	0:00:00	35:37:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	30-11-2023 00:07	30-11-2023 09:57	0:00:00	0:00:00	0:00:00	9:50:00	Line hand tripped as per RLDC instruction due to voltage regulation.	
400 kV Chaibasa-Kharagpur D/C line CKT- 1			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outage in this month	

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of NOV 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of NOV 2023

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil