

Purulia & Kharagpur Transmission Company Limited
I. AC Transmission Line Outage Details for the month of OCT 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 kV Chaibasa-Kharagpur D/C line CKT- 1	14-10-2023 08:24	14-10-2023 16:31	0:00:00	0:00:00	0:00:00	8:07:00	WBSETCL taken the shutdown for tree trimming work.	100.000%
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	30-10-2023 10:31	30-10-2023 11:09	0:00:00	8:07:00	0:00:00	0:00:00	Due to PLCC maloperation at New Ranchi end and DT received at New PPSP end. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	30-10-2023 10:38	30-10-2023 11:14	0:00:00	0:36:00	0:00:00	0:00:00	Due to PLCC maloperation at New Ranchi end and DT received at New PPSP end. Only line portion belongs to PKTCL.	
400 kV Chaibasa-Kharagpur D/C line CKT- 2			0:00:00	0:00:00	0:00:00	0:00:00	NO Tripping/Outage in this month	

Purulia & Kharagpur Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of OCT 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

III. Details of compensation paid by the inter-State transmission licensee for the month of OCT 2023

Schedule III

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil