

**Purulia & Kharagpur Transmission Company Limited**  
**I. AC Transmission Line Outage Details for the month of SEP 2023**

**Schedule I**

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of	%
	Date & Time	Date & Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min	Outage	Availability
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	01-09-2023 00:00	01-09-2023 18:30	0:00:00	0:00:00	0:00:00	18:30:00	Continuously in outage from previous month, WBSETCL taken the shutdown for HV and CRM Testing work for construction of one no. 420KV GIS DIA (one & Half Breaker) at New PPSP Sub-station. Only line portion belongs to PKTCL.	100.000%
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	05-09-2023 08:34	05-09-2023 14:06	0:00	0:00	0:00	5:32	WBSETCL taken the shutdown for construction of one no 420kV GIS DIA(One And Half Breaker) at New PPSP Sub-station. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	07-09-2023 08:10	07-09-2023 15:06	0:00	0:00	0:00	6:56	WBSETCL taken the shutdown for construction of one no 420kV GIS DIA(One And Half Breaker) at New PPSP Sub-station. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	07-09-2023 15:32	07-09-2023 19:30	0:00	3:58	0:00	0:00	Relay Maloperation tripped due to 86 operated at New Ranchi end & DT received at New PPSP end. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-2	14-09-2023 08:13	14-09-2023 10:52	0:00	0:00	0:00	2:39	WBSETCL taken the shutdown for construction of one no 420kV GIS DIA(One And Half Breaker) at New PPSP Sub-station. Only line portion belongs to PKTCL.	
400 KV,D/C New Ranchi-New Purulia Line: CKT-1	26-09-2023 09:48	26-09-2023 19:53	0:00:00	0:00:00	0:00:00	10:05:00	PGCIL Taken the shutdown for AMP work. Only line portion belongs to PKTCL.	
400 kV Chaibasa-Kharagpur D/C line CKT- 1			0:00:00	0:00:00	0:00:00	0:00:00		
400 kV Chaibasa-Kharagpur D/C line CKT- 2			0:00:00	0:00:00	0:00:00	0:00:00		

**Purulia & Kharagpur Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of SEP 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
Nil	Nil	Nil
Nil	Nil	Nil
Nil	Nil	Nil

**III. Details of compensation paid by the inter-State transmission licensee for the month of SEP 2023**

**Schedule III**

Element Name	Violation of Regulation 5(a)		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil