

Ishanagar Power Transmission Limited

REGISTERED OFFICE: CORE-4, SCOPE COMPLEX, 7 LODHI ROAD, DELHI-110003

CIN NO.: U42202DL20203GOI415540

NOTICE

UNDER SUB-SECTION (2) OF SECTION 15 OF THE ELECTRICITY ACT, 2003

1. Ishanagar Power Transmission Limited, having its registered office at Core-4, Scope Complex, 7 Lodhi Road, Delhi-110003 which is incorporated under the Companies Act, 2013 has made up an application before the Central Electricity Regulatory Commission, New Delhi under Sections 14, 15, 79(1)(e) of the Electricity Act, 2003 read with Central Electricity Regulatory Commission (Procedure, Terms and Conditions for Grant of Transmission License and other related matters) Regulations, 2009 seeking Transmission License for Ishanagar Power Transmission Ltd. for the Transmission Project being implemented through Tariff Based Competitive Bidding Process, the details of which are given :

Sl. No.	Name of the line/ substation (location)(Scope of Transmission Scheme)	Line Length/Capacity (Capacity/km)	Levelized Transmission Charges	Commissioning Schedule	Remarks
1	Establishment of 2x1500 MVA, 765/400 kV and 2x500 MVA, 400/220 kV S/s at Ishanagar (New) along with 1x330 MVA, 765 kV & 1x125 MVA, 420 kV bus reactor	<ul style="list-style-type: none">• 765 kV & 1x125 MVA, 420 kV bus reactor• 765/400 kV, 1500 MVA ICT – 2 Nos.(7x500 MVA 1-phase units including one spare ICT unit)• 400/220 kV, 500 MVA ICT – 2 Nos.• 765 kV ICT bays – 2 Nos.• 400 kV ICT bays – 4 Nos.• 220 kV ICT bays – 2 Nos.• 765 kV Line bays – 2 Nos.• 330 MVA, 765 kV Bus Reactor – 1 No. (4x 110 MVA including one spare unit)• 125 MVA, 420 kV Bus reactor – 1 No.• 765 kV Bus reactor bay: 1 No.• 400 kV Bus reactor bay: 1 No.• 220 kV Bus coupler bay- 1 No.• 220 kV Transfer Bus Coupler (TBC) bay - 1 No.• 220 kV line bays – 6 Nos. (for 220 kV lines to be implemented by MPPTCL*) Future provisions: Space for <ul style="list-style-type: none">• 765/400 kV ICT along with bays- 4 Nos.• 765 kV line bays along with switchable line reactors – 8 Nos.• 765 kV Bus Reactor along with bay: 3 Nos.• 765 kV Sectionalizer: 1 set• 400 kV line bays along with switchable line reactor – 10 Nos.• 400/220 kV ICT along with bays -7 Nos.• 400 kV Bus Reactor along with bays: 3 Nos.• 400 kV Sectionalization bay: 1- set• 220 kV line bays: 12 Nos.• 220 kV Sectionalization bay: 2 sets• 220 kV BC and TBC: 2 Nos	INR 625.88 million per annum,	08.02.2026	-
2	LILO of one circuit of Jabalpur - Orai 765 kV D/c line at Ishanagar 765 kV S/s (New)				

2. Complete application and other documents filed before the commission are available on the website <https://www.indigrid.co.in/documents-manager/> for access of any person. The application can also be inspected at the office of the company at 10th Floor, Berger Delhi One, Sector 16B Noida, Uttar Pradesh-201301 with Mr. Lokendra Singh Ranawat or Office of the commission in accordance with the procedure specified by the commission.

3. Objections and suggestions, if any, be filed before the Secretary, Central Electricity Regulatory Commission, 3rd and 4th Floor, Chandarlok Building, 36, Janpath, New Delhi-110001, with a copy to the applicant at the address of its corporate office within 30 days of publication of this notice in the newspaper.

Sd/-

Place: Noida
Date: 29.02.2024

Amitanshu Srivastava
Director