

NER-II Transmission Limited

I. AC Transmission Line Outage Details for the month of May 2023

Schedule I

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | Reason of Outage | % Availability |
|---|------------|----------|-------------|----------|---|----------------|--|--------------------------|--|----------------|
| | Date | Time | Date | Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | | |
| 132kV AGTPP(NEEPCO) - P.K.Bari Ckt-1 | 07-05-2023 | 09:50:00 | 07-05-2023 | 16:09:00 | 0:00 | 0:00 | 0:00 | 6:19 | TSECL taken the shutdown for pre-monsoon remedial maintenance work for the BUS at TSECL P K Bari SS. Shutdown code - 423 Charging Code - 430 | 100.0000% |
| 132kV AGTPP(NEEPCO) - P.K.Bari Ckt-2 | 07-05-2023 | 09:50:00 | 07-05-2023 | 16:10:00 | 0:00 | 0:00 | 0:00 | 6:20 | TSECL taken the shutdown for pre-monsoon remedial maintenance work for the BUS at TSECL P K Bari SS. Shutdown code - 423 Charging Code - 430 | |
| 400kV D/C Slichar-Misa Ckt 1 | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400kV D/C Slichar-Misa Ckt 2 | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 132kV D/C Itanagar-BNC ckt-01 | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 132kV D/C Itanagar-BNC ckt-02 | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400kV Surajmaninagar- P.K.Bari Ckt-1 | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400kV Surajmaninagar- P.K.Bari Ckt-2 | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400/132kV 315 MVA ICT-02 at Surajmani Nagar | 02-05-2023 | 18:23:00 | 03-05-2023 | 00:31:00 | 0:00 | 0:00 | 0:00 | 6:08 | ICT hand tripped as per RLDC instruction due to controlling the overloading issue in 132KV SM Nagar-SM Nagar Line. Shutdown code - 92 Charging Code - 117 | |
| 400/132kV 315 MVA ICT-02 at Surajmani Nagar | 08-05-2023 | 15:17:00 | 09-05-2023 | 00:52:00 | 0:00 | 0:00 | 0:00 | 9:35 | ICT hand tripped as per RLDC instruction due to controlling the overloading issue in 132KV SM Nagar-SM Nagar Line. Shutdown code - 492 Charging Code - 535 | |
| 400/132kV 315 MVA ICT-02 at Surajmani Nagar | 09-05-2023 | 18:03:00 | 11-05-2023 | 06:02:00 | 0:00 | 0:00 | 0:00 | 35:59 | ICT hand tripped as per RLDC instruction due to controlling the overloading issue in 132KV SM Nagar-SM Nagar Line. Shutdown code - 568 Charging Code - 674 | |
| 400/132kV 315 MVA ICT-02 at Surajmani Nagar | 11-05-2023 | 14:45:00 | 12-05-2023 | 05:17:00 | 0:00 | 0:00 | 0:00 | 14:32 | ICT hand tripped as per RLDC instruction due to controlling the overloading issue in 132KV SM Nagar-SM Nagar Line. Shutdown code - 692 Charging Code - 742 | |
| 400/132kV 315 MVA ICT-02 at Surajmani Nagar | 13-05-2023 | 19:01:00 | 14-05-2023 | 06:30:00 | 0:00 | 0:00 | 0:00 | 11:29 | ICT hand tripped as per RLDC instruction due to controlling the overloading issue in 132KV SM Nagar-SM Nagar Line. Shutdown code - 854 Charging Code - 872 | |
| 400/132kV 315 MVA ICT-01 at PK Bari | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400/132kV 315 MVA ICT-02 at PK Bari | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |

NER-II Transmission Limited

I. AC Transmission Line Outage Details for the month of May 2023

Schedule I

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | Reason of Outage | % Availability |
|---|------------|----------|-------------|----------|---|----------------|--|--------------------------|--|----------------|
| | Date | Time | Date | Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | | |
| 400/132kV 315 MVA ICT-01 at Surajmani Nagar | | | | | 0:00 | 0:00 | 0:00 | 0:00 | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400kV Bus Reactor-02 at P.K. Bari | 01-05-2023 | 00:00:00 | 03-05-2023 | 23:54:00 | 0:00 | 0:00 | 0:00 | 71:54 | Continuously in outage from previous month, Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Outage code: 1769/04 Charging code: 184 | |
| 400kV Bus Reactor-02 at SM Nagar | 01-05-2023 | 00:00:00 | 01-06-2023 | 00:00:00 | 0:00 | 0:00 | 0:00 | 744:00 | Continuously in outage from previous month, Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Still Not charged in this month. Outage code: 890/03 Charging code: | |
| 400kV Bus Reactor-02 at P.K. Bari | 04-05-2023 | 12:27:00 | 04-05-2023 | 23:08:00 | 0:00 | 0:00 | 0:00 | 10:41 | Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Outage code: 222 Charging code: 280 | |
| 400kV Bus Reactor-02 at P.K. Bari | 07-05-2023 | 18:19:00 | 12-05-2023 | 03:20:00 | 0:00 | 0:00 | 0:00 | 105:01 | Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Outage code: 445 Charging code: 739 | |
| 400kV Bus Reactor-02 at P.K. Bari | 12-05-2023 | 14:42:00 | 13-05-2023 | 02:38:00 | 0:00 | 0:00 | 0:00 | 11:56 | Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Outage code: 772 Charging code: 809 | |
| 400kV Bus Reactor-01 at P.K. Bari | 13-05-2023 | 08:59:00 | 26-05-2023 | 02:00:00 | 0:00 | 0:00 | 0:00 | 305:01 | Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Outage code: 821 Charging code: 1585 | |
| 400kV Bus Reactor-01 at SM Nagar | 15-05-2023 | 10:46:00 | 15-05-2023 | 22:14:00 | 0:00 | 0:00 | 0:00 | 11:28 | Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Outage code: 941 Charging code: 985 | |
| 400kV Bus Reactor-02 at P.K. Bari | 26-05-2023 | 11:42:00 | 01-06-2023 | 00:00:00 | 0:00 | 0:00 | 0:00 | 132:18 | Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Still not charged in this month. Outage code: 1604 Charging code: | |

NER-II Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2023

Schedule II

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|---|-----------------------------------|
| Nil | Nil | Nil |
| Nil | Nil | Nil |

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2023

Schedule III

| Element Name | Violation of Regulation | | Violation of Regulation 5(b) | | Compensation paid (in Rs) |
|--------------|---------------------------|-----------------------|---------------------------------------|-----------------------------------|---------------------------|
| | % Availability prescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Total | | | | | Nil |