

NER-II Transmission Limited

I. AC Transmission Line Outage Details for the month of November 2023

Schedule I

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | Reason of Outage | % Availability |
|---|------------|-------|-------------|-------|---|----------------|--|--------------------------|---|----------------|
| | Date | Time | Date | Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | | |
| 132kV AGTTPP(NEEPCO) - P.K.Bari Ckt-2 | 05-11-2023 | 09:28 | 05-11-2023 | 12:43 | | | | 3:15 | Due to Bus-1 outage at Neepco end. Shutdown availed by NEEPCO. Shutdown code - 308 Charging Code - 314 | 99.9003% |
| 132kV AGTTPP(NEEPCO) - P.K.Bari Ckt-2 | 07-11-2023 | 10:28 | 07-11-2023 | 13:07 | 2:39 | | | | Emergency shutdown taken for rectification of the damaged contacts and alignment issue of 132kV Bus isolator at Neepco end. Shutdown code - 450 Charging Code - 456 | |
| 132kV AGTTPP(NEEPCO) - P.K.Bari Ckt-2 | 14-11-2023 | 10:11 | 14-11-2023 | 15:25 | 5:14 | | | | Line tripped from Neepco end & A/R from PK Bari end due to Y-phase to Earth Fault. Line taken E/S at 14:13 hrs against the code 983 for CVT R-phase fuse replacement Shutdown code - Charging Code - 991 | |
| 132kV AGTTPP(NEEPCO) - P.K.Bari Ckt-2 | 17-11-2023 | 18:51 | 17-11-2023 | 20:23 | 1:32 | | | | Line tripped due to B-Ph to Earth fault Shutdown code - Charging Code - 1261 | |
| 132kV AGTTPP(NEEPCO) - P.K.Bari Ckt-1 | 17-11-2023 | 01:34 | 18-11-2023 | 17:16 | | | 39:42 | | Line tripped due to B-Ph to Earth fault due to lightning. Enclosed herewith the IMD Report and the photograph of the insulator. Shutdown code - Charging Code - 1329 | |
| 400kV D/C Silchar-Misa Ckt 2 | 17-11-2023 | 21:35 | 18-11-2023 | 19:03 | | | 21:28 | | Line tripped on phase to Earth fault due to lightning. Tripping converted to emergency shutdown for replacement of faulty Insulator due to lightning. Enclosed here with the IMD report and the photograph of insulator. Shutdown code - Charging Code - 1347 | |
| 132kV AGTTPP(NEEPCO) - P.K.Bari Ckt-1 | 25-11-2023 | 09:37 | 25-11-2023 | 14:43 | | | 5:06 | | Emergency shutdown taken for replacement of faulty insulator in B-phase due to lightning on 17-11-2023. Enclosed herewith the photograph of the insulator. Shutdown code - 1777 Charging Code - 1784 | |
| 400kV Surajmaninagar- P.K.Bari Ckt-1 | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400kV Surajmaninagar- P.K.Bari Ckt-2 | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400kV D/C Silchar-Misa Ckt 1 | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 132kV D/C Itanagar-BNC ckt-01 | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 132kV BNC-Gohpur ckt-01 | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 132kV Gohpur-Itanagar ckt-01 | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400/132kV 315 MVA ICT-02 at Surajmani Nagar | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400/132kV 315 MVA ICT-01 at PK Bari | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400/132kV 315 MVA ICT-02 at PK Bari | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |
| 400/132kV 315 MVA ICT-01 at Surajmani Nagar | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |

NER-II Transmission Limited

I. AC Transmission Line Outage Details for the month of November 2023

Schedule I

| Element Name | Outage | | Restoration | | Duration of Outage Attributable to | | | | Reason of Outage | % |
|-----------------------------------|------------|-------|-------------|-------|--|-------------------|---|-----------------------------|--|---|
| | Date | Time | Date | Time | Inter-State Transmission Licensee Hrs:Min | Others Hrs:Min | System constraint/ Natural calamity/ Militancy Hrs:Min | Deemed Available Hrs:Min | | |
| 400kV Bus Reactor-02 at SM Nagar | 01-11-2023 | 00:00 | 30-11-2023 | 00:00 | | | | 696:00 | Continuously in outage from August. Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Still not charged in this month. Outage code: 1267/08 Charging code: | |
| 400kV Bus Reactor-01 at P.K. Bari | 01-11-2023 | 00:00 | 20-11-2023 | 21:46 | | | | 477:46 | Continuously in outage from last month. Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Outage code: 1812 Charging code: 1494 | |
| 400kV Bus Reactor-01 at SM Nagar | 21-11-2023 | 09:36 | 30-11-2023 | 00:00 | | | | 206:24 | Bus Reactor Hand Tripped as per RLDC instruction due to voltage regulation. Still not charged in this month. Outage code: 11514 Charging code: | |
| 400kV Bus Reactor-02 at P.K. Bari | | | | | | | | | NO Tripping / Outages in this month Shutdown code - Charging Code - | |

NER-II Transmission Limited**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of November 2023****Schedule II**

| Element Name | Restoration time as specified in Regulation 5 (b) (in days) | Actual restoration time (in days) |
|--------------|---|-----------------------------------|
| Nil | Nil | Nil |
| Nil | Nil | Nil |

III. Details of compensation paid by the inter-State transmission licensee for the month of November 2023**Schedule III**

| Element Name | Violation of Regulation | | Violation of Regulation 5(b) | | Compensation paid (in Rs) |
|--------------|---------------------------|-----------------------|---------------------------------------|-----------------------------------|---------------------------|
| | % Availability prescribed | Actual % Availability | Restoration time prescribed (in days) | Actual restoration time (in days) | |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Nil | Nil | Nil | Nil | Nil | Nil |
| Total | | | | | Nil |