

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of April 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV D/C Sohna Road(GPTL) - Gurgaon(PG) Ckt-1	03-04-2023 16:10	03-04-2023 19:10	00:00	00:00	00:00	03:00	Line tripped Due to R-phase to earth fault. Fault distance is at 6.42 kms from Sohna Road Substaion however only 480 mtrs fall under the purview / ownership of the GPTL & fault occurred in PowerGrid line section.	100.00%

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)		Actual restoration time (in days)			
	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)				
400kV D/C Slichar-Misa Ckt 1	Nil	Nil	-			
400kV D/C Slichar-Misa Ckt 2	Nil	Nil	-			

III. Details of compensation paid by the inter-State transmission licensee for the month of April 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil