

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of August 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available				
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min				
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	01-08-2023 00:00	12-08-2023 07:25	00:00	00:00	00:00	271:25	Continuously in outage from Previous Month, Bus reactor taken out as per NRLDC instructions due to voltage regulation.	100.00%		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	01-08-2023 00:00	06-08-2023 19:11	00:00	00:00	00:00	139:11	Continuously in outage from Previous Month, Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	01-08-2023 20:20	15-08-2023 17:19	00:00	00:00	00:00	332:59	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	07-08-2023 10:17	15-08-2023 17:11	00:00	00:00	00:00	198:54	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	13-08-2023 22:37	01-09-2023 00:00	00:00	00:00	00:00	433:23	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	16-08-2023 10:13	01-09-2023 00:00	00:00	00:00	00:00	373:47	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	16-08-2023 10:47	01-09-2023 00:00	00:00	00:00	00:00	373:13	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.			
400kV Neemrana (PG) -Dhanodha (HVPNL) -2	22-08-2023 18:58	23-08-2023 08:08	00:00	0:00	00:00	13:10	HVPNL taken the emergency shutdown for attending the heavy spark was observed at tie bay isolator (417 No. bay -R phase) at Dhanodha Substation. Line open manually by HVPNL after taking permission from SLDC Haryana (Without Grid code) for emergency purpose at 1858 hrs on 23-08-2023. Line connected through TIE BAY of Only as per the NRLDC instruction ( Lines Main bay were under shutdown as per system constrain and as pe NRLDC instruction. The said Bay no. 417 ownership belongs to HVPNL. Accordingly outage will not be attributable to GPTL.			

**Gurgaon Palwal Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of August 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)		Actual restoration time (in days)			
	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)				
400kV D/C Slichar-Misa Ckt 1	Nil	Nil	-			
400kV D/C Slichar-Misa Ckt 2	Nil	Nil	-			

**III. Details of compensation paid by the inter-State transmission licensee for the month of August 2023**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil