

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of December 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available				
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min				
400/220kV 500 MVA ICT-1 at Kadarapur(GPTL)	02-12-2023 09:15	02-12-2023 20:45	11:30:00	0:00:00	0:00:00	0:00:00		For AMP works of Bay.		
400/220kV 500 MVA ICT-2 at Kadarapur(GPTL)	04-12-2023 08:50	04-12-2023 21:36	12:46:00	0:00:00	0:00:00	0:00:00		For AMP works of Bay.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	06-12-2023 08:36	06-12-2023 17:48	09:12	00:00	00:00	0:00		For AMP works of the Reactor.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	08-12-2023 09:28	08-12-2023 15:19	00:00	00:00	00:00	5:51		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	08-12-2023 09:40	08-12-2023 15:13	00:00	00:00	00:00	5:33		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	08-12-2023 09:32	11-12-2023 22:57	00:00	00:00	00:00	85:25		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	09-12-2023 09:28	09-12-2023 19:43	00:00	00:00	00:00	10:15		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	09-12-2023 09:25	09-12-2023 14:51	00:00	0:00	00:00	05:26		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	11-12-2023 10:35	11-12-2023 13:51	00:00	0:00	00:00	03:16		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	11-12-2023 09:32	11-12-2023 22:57	00:00	0:00	00:00	13:25		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	12-12-2023 09:50	12-12-2023 19:26	00:00	0:00	00:00	09:36		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	12-12-2023 08:46	13-12-2023 20:57	00:00	0:00	00:00	36:11		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	13-12-2023 09:46	13-12-2023 16:30	00:00	0:00	00:00	06:44		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	13-12-2023 09:53	13-12-2023 20:54	00:00	0:00	00:00	11:01		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	14-12-2023 10:39	14-12-2023 16:07	00:00	0:00	00:00	05:28		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	15-12-2023 09:44	15-12-2023 16:11	00:00	0:00	00:00	06:27		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	15-12-2023 09:40	15-12-2023 16:00	00:00	0:00	00:00	06:20		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	16-12-2023 09:36	16-12-2023 15:26	00:00	0:00	00:00	05:50		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	16-12-2023 09:41	16-12-2023 15:21	00:00	0:00	00:00	05:40		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	16-12-2023 09:24	17-12-2023 18:45	00:00	0:00	00:00	33:21		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	17-12-2023 09:26	17-12-2023 15:12	00:00	0:00	00:00	05:46		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	17-12-2023 09:27	17-12-2023 15:19	00:00	0:00	00:00	05:52		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	18-12-2023 09:23	18-12-2023 16:53	00:00	0:00	00:00	07:30		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	18-12-2023 08:59	18-12-2023 17:47	00:00	0:00	00:00	08:48		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	18-12-2023 09:07	18-12-2023 17:36	00:00	0:00	00:00	08:29		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	19-12-2023 08:59	19-12-2023 17:25	00:00	0:00	00:00	08:26		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	19-12-2023 09:12	19-12-2023 18:11	00:00	0:00	00:00	08:59		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	19-12-2023 08:55	19-12-2023 17:38	00:00	0:00	00:00	08:43		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	20-12-2023 09:35	20-12-2023 21:02	00:00	0:00	00:00	11:27		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	20-12-2023 09:20	20-12-2023 21:09	00:00	0:00	00:00	11:49		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	20-12-2023 09:14	20-12-2023 21:15	00:00	0:00	00:00	12:01		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	21-12-2023 09:56	21-12-2023 16:45	00:00	0:00	00:00	06:49		Bus reactor taken out as per NRLDC instructions due to voltage regulation.	99.79%	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	21-12-2023 10:25	21-12-2023 17:01	00:00	0:00	00:00	06:36		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	21-12-2023 10:08	21-12-2023 16:54	00:00	0:00	00:00	06:46		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	22-12-2023 09:50	22-12-2023 15:30	00:00	0:00	00:00	05:40		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of December 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available				
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min				
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	22-12-2023 09:42	22-12-2023 15:36	00:00	0:00	00:00	05:54	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	23-12-2023 10:42	23-12-2023 16:53	00:00	0:00	00:00	06:11	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	23-12-2023 09:22	23-12-2023 17:03	00:00	0:00	00:00	07:41	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	23-12-2023 09:40	23-12-2023 16:46	00:00	0:00	00:00	07:06	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	24-12-2023 10:22	24-12-2023 18:09	00:00	0:00	00:00	07:47	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	24-12-2023 09:59	24-12-2023 18:21	00:00	0:00	00:00	08:22	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	25-12-2023 09:50	25-12-2023 18:55	00:00	0:00	00:00	09:05	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	25-12-2023 09:43	25-12-2023 18:20	00:00	0:00	00:00	08:37	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	25-12-2023 09:59	25-12-2023 18:47	00:00	0:00	00:00	08:48	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	26-12-2023 10:08	26-12-2023 18:42	00:00	0:00	00:00	08:34	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	26-12-2023 09:48	26-12-2023 18:36	00:00	0:00	00:00	08:48	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	26-12-2023 09:53	26-12-2023 18:33	00:00	0:00	00:00	08:40	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	27-12-2023 09:38	27-12-2023 19:59	00:00	0:00	00:00	10:21	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	27-12-2023 09:32	27-12-2023 19:52	00:00	0:00	00:00	10:20	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	27-12-2023 09:27	27-12-2023 19:57	00:00	0:00	00:00	10:30	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	28-12-2023 10:28	28-12-2023 17:02	00:00	0:00	00:00	06:34	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	28-12-2023 10:38	28-12-2023 17:00	00:00	0:00	00:00	06:22	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	29-12-2023 11:03	29-12-2023 15:38	00:00	0:00	00:00	04:35	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	29-12-2023 11:01	29-12-2023 15:47	00:00	0:00	00:00	04:46	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	29-12-2023 11:05	29-12-2023 15:56	00:00	0:00	00:00	04:51	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	30-12-2023 10:23	30-12-2023 16:05	00:00	0:00	00:00	05:42	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	30-12-2023 10:18	30-12-2023 16:26	00:00	0:00	00:00	06:08	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	30-12-2023 10:16	30-12-2023 17:18	00:00	0:00	00:00	07:02	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	31-12-2023 09:32	31-12-2023 16:22	00:00	0:00	00:00	06:50	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	31-12-2023 09:14	31-12-2023 16:13	00:00	0:00	00:00	06:59	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	31-12-2023 09:19	31-12-2023 16:59	00:00	0:00	00:00	07:40	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of December 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)		Actual restoration time (in days)			
	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)				
400kV D/C Slichar-Misa Ckt 1	Nil	Nil	-			
400kV D/C Slichar-Misa Ckt 2	Nil	Nil	-			

III. Details of compensation paid by the inter-State transmission licensee for the month of December 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil