

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of February 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available				
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min				
400/220kV 500 MVA ICT-2 at SOHNA ROAD(GPTL)	14-02-2024 09:07	14-02-2024 20:50	11:43:00	0:00:00	0:00:00	0:00:00	GPTL Taken the shutdown for AMP works.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	01-02-2024 11:55	01-02-2024 15:47	0:00:00	0:00:00	0:00:00	3:52:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	01-02-2024 12:02	01-02-2024 15:41	00:00	00:00	00:00	3:39	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	01-02-2024 11:58	01-02-2024 15:56	00:00	00:00	00:00	3:58	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	02-02-2024 10:04	02-02-2024 15:07	00:00	00:00	00:00	5:03	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	02-02-2024 10:07	02-02-2024 15:04	00:00	00:00	00:00	4:57	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	02-02-2024 10:09	02-02-2024 14:59	00:00	00:00	00:00	4:50	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	03-02-2024 10:20	03-02-2024 14:58	00:00	0:00	00:00	04:38	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	03-02-2024 09:44	03-02-2024 14:56	00:00	0:00	00:00	05:12	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	06-02-2024 09:51	06-02-2024 20:52	00:00	0:00	00:00	11:01	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	06-02-2024 09:38	06-02-2024 13:23	00:00	0:00	00:00	03:45	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	06-02-2024 09:44	06-02-2024 16:57	00:00	0:00	00:00	07:13	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	08-02-2024 10:53	08-02-2024 21:26	00:00	0:00	00:00	10:33	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	08-02-2024 10:45	08-02-2024 21:29	00:00	0:00	00:00	10:44	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	08-02-2024 10:50	08-02-2024 21:33	00:00	0:00	00:00	10:43	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	09-02-2024 09:20	09-02-2024 21:13	00:00	0:00	00:00	11:53	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	09-02-2024 09:43	09-02-2024 21:07	00:00	0:00	00:00	11:24	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	09-02-2024 09:45	09-02-2024 21:16	00:00	0:00	00:00	11:31	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	10-02-2024 09:10	10-02-2024 17:14	00:00	0:00	00:00	08:04	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	10-02-2024 09:17	10-02-2024 15:16	00:00	0:00	00:00	05:59	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	10-02-2024 09:35	10-02-2024 15:13	00:00	0:00	00:00	05:38	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	11-02-2024 09:56	11-02-2024 15:23	00:00	0:00	00:00	05:27	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	11-02-2024 09:59	11-02-2024 15:14	00:00	0:00	00:00	05:15	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	11-02-2024 09:54	11-02-2024 15:09	00:00	0:00	00:00	05:15	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	12-02-2024 09:20	12-02-2024 16:54	00:00	0:00	00:00	07:34	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	12-02-2024 09:17	12-02-2024 17:05	00:00	0:00	00:00	07:48	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	12-02-2024 09:18	12-02-2024 18:52	00:00	0:00	00:00	09:34	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	13-02-2024 08:45	13-02-2024 16:16	00:00	0:00	00:00	07:31	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	13-02-2024 08:52	14-02-2024 19:06	00:00	0:00	00:00	34:14	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	13-02-2024 08:48	13-02-2024 16:19	00:00	0:00	00:00	07:31	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	14-02-2024 07:15	14-02-2024 16:22	00:00	0:00	00:00	09:07	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	14-02-2024 07:12	14-02-2024 16:10	00:00	0:00	00:00	08:58	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	15-02-2024 09:24	15-02-2024 16:51	00:00	0:00	00:00	07:27	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	15-02-2024 09:10	15-02-2024 20:59	00:00	0:00	00:00	11:49	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	15-02-2024 09:12	15-02-2024 21:02	00:00	0:00	00:00	11:50	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of February 2024

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available				
								Hrs:Min		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	16-02-2024 07:38	16-02-2024 17:12	00:00	0:00	00:00	09:34	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	16-02-2024 07:45	16-02-2024 17:15	00:00	0:00	00:00	09:30	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	16-02-2024 07:42	16-02-2024 17:17	00:00	0:00	00:00	09:35	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	17-02-2024 09:42	17-02-2024 15:35	00:00	0:00	00:00	05:53	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	17-02-2024 09:38	17-02-2024 15:39	00:00	0:00	00:00	06:01	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	17-02-2024 09:41	17-02-2024 15:41	00:00	0:00	00:00	06:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	18-02-2024 11:15	18-02-2024 14:35	00:00	0:00	00:00	03:20	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	18-02-2024 10:56	18-02-2024 14:39	00:00	0:00	00:00	03:43	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	18-02-2024 11:17	18-02-2024 14:42	00:00	0:00	00:00	03:25	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	20-02-2024 11:03	20-02-2024 13:15	00:00	0:00	00:00	02:12	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	20-02-2024 10:48	20-02-2024 13:21	00:00	0:00	00:00	02:33	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	20-02-2024 10:54	20-02-2024 13:26	00:00	0:00	00:00	02:32	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	21-02-2024 10:17	21-02-2024 13:12	00:00	0:00	00:00	02:55	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	21-02-2024 10:09	21-02-2024 13:16	00:00	0:00	00:00	03:07	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	21-02-2024 10:01	21-02-2024 13:02	00:00	0:00	00:00	03:01	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	22-02-2024 10:18	22-02-2024 17:26	00:00	0:00	00:00	07:08	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	22-02-2024 09:31	22-02-2024 17:28	00:00	0:00	00:00	07:57	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	23-02-2024 09:20	23-02-2024 17:04	00:00	0:00	00:00	07:44	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	23-02-2024 10:02	23-02-2024 17:13	00:00	0:00	00:00	07:11	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	23-02-2024 09:23	23-02-2024 17:06	00:00	0:00	00:00	07:43	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	24-02-2024 09:37	24-02-2024 16:22	00:00	0:00	00:00	06:45	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	24-02-2024 09:39	24-02-2024 16:19	00:00	0:00	00:00	06:40	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	25-02-2024 09:23	25-02-2024 16:27	00:00	0:00	00:00	07:04	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	25-02-2024 09:27	25-02-2024 16:32	00:00	0:00	00:00	07:05	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	25-02-2024 09:32	25-02-2024 16:25	00:00	0:00	00:00	06:53	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	26-02-2024 09:52	26-02-2024 17:53	00:00	0:00	00:00	08:01	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	26-02-2024 09:57	26-02-2024 15:26	00:00	0:00	00:00	05:29	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	26-02-2024 10:03	26-02-2024 15:32	00:00	0:00	00:00	05:29	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	27-02-2024 09:36	27-02-2024 15:47	00:00	0:00	00:00	06:11	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	27-02-2024 09:41	27-02-2024 14:50	00:00	0:00	00:00	05:09	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	28-02-2024 09:59	28-02-2024 13:28	00:00	0:00	00:00	03:29	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	28-02-2024 09:35	28-02-2024 13:42	00:00	0:00	00:00	04:07	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	28-02-2024 09:47	28-02-2024 13:24	00:00	0:00	00:00	03:37	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Prithala(GPTL)	29-02-2024 08:58	29-02-2024 16:13	00:00	0:00	00:00	07:15	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of February 2024

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	29-02-2024 09:03	29-02-2024 16:24	00:00	0:00	00:00	07:21	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	29-02-2024 09:17	29-02-2024 16:22	00:00	0:00	00:00	07:05	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV Neemrana (PG) -Dhanodha (HVPNL) -2	20-02-2024 14:24	20-02-2024 16:20	00:00	0:00	00:00	01:56	HVPNL taken the emergency shutdown for attending the hot spot on R-Phase Tie Bay (417) isolator at Dhanodha end, Tie Bay under the ownership of HVPNL.	
400kV D/C Aligarh-Prithala Ckt-1	24-02-2024 17:49	24-02-2024 20:12	00:00	0:00	00:00	02:23	Shutdown availed by PGCIL for attending hotspot in 400 kV Prithala -1 (B & R phase) wave trap droppers at PGCIL Aligarh Substation.	
400kV D/C Aligarh-Prithala Ckt-2	24-02-2024 20:34	24-02-2024 23:35	00:00	0:00	00:00	03:01	Shutdown availed by PGCIL for attending hotspot in 400 kV Prithala -1 (B & R phase) wave trap droppers at PGCIL Aligarh Substation.	

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of February 2024

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)		Actual restoration time (in days)			
	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)				
400kV D/C Slichar-Misa Ckt 1	Nil	Nil	-			
400kV D/C Slichar-Misa Ckt 2	Nil	Nil	-			

III. Details of compensation paid by the inter-State transmission licensee for the month of February 2024

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil