

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of June 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD	08-06-2023 12:23	08-06-2023 16:16	00:00	00:00	00:00	03:53	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	99.9958%
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	08-06-2023 12:31	08-06-2023 15:15	00:00	00:00	00:00	02:44	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPT)	08-06-2023 12:37	08-06-2023 15:21	00:00	00:00	00:00	02:44	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPT)	09-06-2023 10:28	18-06-2023 16:06	00:00	00:00	00:00	221:38	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD	09-06-2023 10:17	18-06-2023 15:51	00:00	00:00	00:00	221:34	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	09-06-2023 10:38	18-06-2023 15:58	00:00	00:00	00:00	221:20	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD	23-06-2023 11:48	25-06-2023 03:42	00:00	00:00	00:00	39:54	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPT)	23-06-2023 11:53	23-06-2023 17:19	00:00	00:00	00:00	05:26	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	23-06-2023 12:06	25-06-2023 10:05	00:00	00:00	00:00	45:59	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPT)	24-06-2023 11:44	25-06-2023 09:54	00:00	00:00	00:00	22:10	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV Neemrana (PG) -Dhanodha (HVPNL) -2	21-06-2023 17:24	21-06-2023 21:35	00:00	4:11	00:00	00:00	Tripping encountered due to R-Phase to Earth fault in 400KV Mahendragarh - Dhanonda Ckt-1 and because of the same the 400KV D/C Neemrana-Dhanonda Ckt-02 tripped at same time (17:24Hrs) as both Line connected through TIE BAY Only as per the NRLDC instruction ( Both lines main bay were under shutdown).	
400kV Kadarapur(GPTL) - Sohna Road(GPTL) Ckt-1	26-06-2023 10:55	26-06-2023 12:20	1:25	00:00	00:00	00:00	To attend hotspot in Y-Phase of 400 KV Kadarapur -Sohna Road (GPTL) Ckt-1 at Tower No. 28.	

**Gurgaon Palwal Transmission Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of June 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)		Actual restoration time (in days)			
	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)				
400kV D/C Slichar-Misa Ckt 1	Nil	Nil	-			
400kV D/C Slichar-Misa Ckt 2	Nil	Nil	-			

**III. Details of compensation paid by the inter-State transmission licensee for the month of June 2023**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
<b>Total</b>					Nil