

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of May 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV 125 MVAR Bus Reactor-1 at Kadarpur(GPTL)	23-05-2023 10:42	23-05-2023 18:08	00:00	00:00	00:00	07:26	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	100.00%
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	23-05-2023 11:01	23-05-2023 18:00	00:00	00:00	00:00	06:59	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV, 125MVAR Bus Reactor-1 at Prithala(GPTL)	23-05-2023 10:56	23-05-2023 18:13	00:00	00:00	00:00	07:17	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	25-05-2023 11:44	25-05-2023 17:53	00:00	00:00	00:00	06:09	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400KV, 125MVAR Bus Reactor-1 at Prithala(GPTL)	25-05-2023 11:49	25-05-2023 18:04	00:00	00:00	00:00	06:15	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400kV 125 MVAR Bus Reactor-1 at Kadarpur(GPTL)	25-05-2023 11:47	25-05-2023 18:13	00:00	00:00	00:00	06:26	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of May 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)		Actual restoration time (in days)			
	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)				
400kV D/C Slichar-Misa Ckt 1	Nil	Nil	-			
400kV D/C Slichar-Misa Ckt 2	Nil	Nil	-			

III. Details of compensation paid by the inter-State transmission licensee for the month of May 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil