

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of October 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available				
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min				
400/200kV,500MVA ICT-01 at Prithala(GPTL)	03-10-2023 08:12	03-10-2023 21:57	13:45	00:00	00:00	0:00	Planned shutdown availd by the GPTL for carrying out the annual maintenance works.	99.76%		
400/200kV,500MVA ICT-02 at Prithala(GPTL)	04-10-2023 08:26	04-10-2023 21:10	12:44	00:00	00:00	0:00	Planned shutdown availd by the GPTL for carrying out the annual maintenance works.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	06-10-2023 08:23	06-10-2023 19:11	10:48	00:00	00:00	0:00	Planned shutdown availd by the GPTL for carrying out the annual maintenance works.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	01-10-2023 00:00	06-10-2023 08:23	00:00	00:00	00:00	128:23	Continuously in outage from previous month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	01-10-2023 00:00	02-10-2023 04:17	00:00	00:00	00:00	28:17	Continuously in outage from previous month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	05-10-2023 12:45	29-10-2023 04:01	00:00	00:00	00:00	567:16	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	05-10-2023 12:48	07-10-2023 19:04	00:00	00:00	00:00	54:16	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400kV 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	13-10-2023 11:12	15-10-2023 21:56	00:00	0:00	00:00	58:44	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	13-10-2023 11:03	15-10-2023 21:43	00:00	0:00	00:00	58:40	Bus reactor taken out as per NRLDC instructions due to voltage regulation.			
400KV D/C Neemrana-Dhanonda TL CKT-II	09-10-2023 11:46	09-10-2023 16:07	00:00	0:00	00:00	04:21	HVPNL had taken the emergency shutdown for attending for attending hotspot on R-phase 89B Tie isolator bay 417. Tie Bay ownership belongs to HVPNL. 400KV Mahendragarh – Dhanonda Ckt-1 and 400KV D/C Neemrana-Dhanonda Ckt-02, both Line connected through TIE BAY Only as per the NRLDC instrcution (Both lines main bay were under shutdown).			

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of October 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)		Actual restoration time (in days)			
	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)				
400kV D/C Slichar-Misa Ckt 1	Nil	Nil	-			
400kV D/C Slichar-Misa Ckt 2	Nil	Nil	-			

III. Details of compensation paid by the inter-State transmission licensee for the month of October 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil