

Gurgaon Palwal Transmission Limited

I. AC Transmission Line Outage Details for the month of September 2023

Schedule I

Element Name	Outage		Restoration		Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available				
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min				
400KV D/C Neemrana-Dhanonda TL CKT-I	21-09-2023 11:03	21-09-2023 17:49	06:46	00:00	00:00	0:00		Planned shutdown availd by the GPTL for defect rectification works. Charging Clearance was given at 17:40Hrs and charging code received at 17:49Hrs, However, there was a delay at PGCIL Nimarana SS due to an isolator issue, and the line was ultimately charged at 19:30Hrs. Kindly please consider the extra outage period into Others category. Enclosed here with the email communication.	99.80%	
400KV D/C Neemrana-Dhanonda TL CKT-I	21-09-2023 17:49	21-09-2023 19:30	00:00	01:41	00:00	0:00		Charging Clearance was given at 17:40Hrs and charging code received at 17:49Hrs, However, there was a delay at PGCIL Nimarana SS due to an isolator issue, and the line was ultimately charged at 19:30Hrs. Kindly please consider the extra outage period into Others category.		
400KV D/C Neemrana-Dhanonda TL CKT-II	23-09-2023 10:33	23-09-2023 17:50	07:17	00:00	00:00	0:00		Planned shutdown availd by the GPTL for defect rectification works. Charging Clearance was given at 17:10Hrs and charging code received at 17:50Hrs, However, there was a delay at PGCIL Nimarana SS due to unknown reason, and the line was ultimately charged at 18:20Hrs. Kindly please consider the extra outage period into Others category. Enclosed here with the email communication.		
400KV D/C Neemrana-Dhanonda TL CKT-II	23-09-2023 17:50	23-09-2023 18:20	00:00	00:30	00:00	0:00		Charging Clearance was given at 17:10Hrs and charging code received at 17:50Hrs, However, there was a delay at PGCIL Nimarana SS due to unknown reason, and the line was ultimately charged at 18:20Hrs. Kindly please consider the extra outage period into Others category.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	01-09-2023 00:00	10-09-2023 11:11	00:00	00:00	00:00	227:11		Continuously in outage from previous month, Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kv 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	01-09-2023 00:00	10-09-2023 11:19	00:00	00:00	00:00	227:19		Continuously in outage from previous month, Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kv 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	01-09-2023 00:00	18-09-2023 02:00	00:00	00:00	00:00	410:00		Continuously in outage from previous month, Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kv 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	19-09-2023 12:13	20-09-2023 04:09	00:00	0:00	00:00	15:56		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	19-09-2023 10:49	20-09-2023 04:18	00:00	0:00	00:00	17:29		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kv 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	19-09-2023 12:12	24-09-2023 03:01	00:00	0:00	00:00	110:49		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400kv 125 MVAR Bus Reactor-1 at SOHNA ROAD(GPTL)	20-09-2023 10:52	22-09-2023 04:09	00:00	0:00	00:00	41:17		Bus reactor taken out as per NRLDC instructions due to voltage regulation.		
400KV,125MVAR Bus Reactor-1 at Prithala(GPTL)	20-09-2023 10:53	01-10-2023 00:00	00:00	0:00	00:00	253:07		Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.		
400kv 125 MVAR Bus Reactor-1 at Kadarapur(GPTL)	27-09-2023 11:19	01-10-2023 00:00	00:00	0:00	00:00	84:41		Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.		
400kv D/C Sohna Road(GPTL) - Gurgaon(PG) Ckt-1	15-09-2023 10:18	15-09-2023 11:57	00:00	0:00	00:00	01:39		PGCIL had taken the emergency shutdown for attending for removal of kite threads in (Bay no. 407-B ph.) From Gantry to 400kv Bushing. The said bay belongs to the PGCIL at 400kV Gurgaon Substation. Accordingly outage will not be attributable to GPTL.		

Gurgaon Palwal Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of September 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)		Actual restoration time (in days)			
	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)				
400kV D/C Slichar-Misa Ckt 1	Nil	Nil	-			
400kV D/C Slichar-Misa Ckt 2	Nil	Nil	-			

III. Details of compensation paid by the inter-State transmission licensee for the month of September 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
Nil	Nil	Nil	Nil	Nil	Nil
Nil	Nil	Nil	Nil	Nil	Nil
Total					Nil