#### NRSS-XXIX Transmission Limited

#### I. AC Transmission Line Outage Details for the month of April 2023

Schedule I

	Outage	Restoration	Duration of Outage Attributable to					
Element Name	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available	Reason of Outage	% Availability
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV, 3-Ph 63 MVAR Bus Reactor-2	01/04/2023 00:00	13/04/2023 01:30	0:00	0:00	0:00	289:30	Continuously under outage from previous month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1	01/04/2023 00:00	14/04/2023 01:16	0:00	0:00	0:00	313:16	Continuously under outage from previous month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2	13/04/2023 08:55	01/05/2023 00:00	0:00	0:00	0:00	423:05	Bus reactor taken out as per NRLDC instructions due to voltage regulation and also continued for this month.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1	14/04/2023 08:38	01/05/2023 00:00	0:00	0:00	0:00	399:22	Bus reactor taken out as per NRLDC instructions due to voltage regulation and also continued for this month.	99.9513%
400kV Sambha-Amargarh Ckt-1	11/04/2023 14:32	11/04/2023 14:48	0:00	0:00	0:00	0:16	Line hand tripped as per NRLDC instruction due to volatge regulation for taking back fixed line reactor into service at both end.	
400kV Sambha-Amargarh Ckt-2	12/04/2023 12:18	12/04/2023 12:37	0:00	0:00	0:00	0:19	Line hand tripped as per NRLDC instruction due to volatge regulation for taking back fixed line reactor into service at both end.	
400 kV Jalandhar (PG)-Samba (PG)-I	14/04/2023 13:34	14/04/2023 16:55	3:21	0:00	0:00	0:00	Line Tripped due to R phase to Earth fault (Line again tripped at 15:00 Hrs while taking test charging attempt from Samba end due to R- Phase to Earth Fault. SOTF operated.)	
			1		1			

### **NRSS-XXIX** Transmission Limited

# II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of April 2023

Schedule II

	Restoration time as specified in	Actual restoration time		
Element Name	Regulation 5 (b)	(in days)		
	(in days)			
NIL	NIL	NIL		
NIL	NIL	NIL		
NIL	NIL	NIL		

## III. Details of compensation paid by the inter-State transmission licensee for the month of April 2023

Schedule III

Element Name	Violation of Regulation		Violation of R		
	%		Restoration time	Actual restoration	
	Availability prescribed		prescribed	time	Compensation paid (in Rs)
			(in days)	(in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
	NIL				