NRSS-XXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of July 2023.

	Outage	Dontonation.	Restoration Duration of Outage Attributable to			1		
Element Name	Outage Date Time	Date Time	Inter-State Transmission Licensee	Inter-State ransmission		Deemed Available	Reason of Outage	% Availability
· ·			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	01/07/2023 00:00	21/07/2023 21:10	0:00	0:00	0:00	501:10	Continuously in outage from April-23.Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	01/07/2023 00:00	18/07/2023 18:43	0:00	0:00	0:00	426:43	Continuously in outage from April-23.Bus reactor taken out as per NRLDC instructions due to voltage regulation.	100.00%
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	21/07/2023 21:04	01/08/2023 00:00	0:00	0:00	0:00		Bus reactor taken out as per NRLDC instructions due to voltage regulation and continued for the month.	

Schedule I

NRSS-XXIX Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of July 2023

Schedule II

	Restoration time as specified in	Actual restoration time		
Element Name	Regulation 5 (b)	(in days)		
	(in days)			
NIL	NIL	NIL		
NIL	NIL	NIL		
NIL	NIL	NIL		

III. Details of compensation paid by the inter-State transmission licensee for the month of July 2023

Schedule III

Element Name	Violation of Regulation		Violation of R		
	%		Restoration time	Actual restoration	
	Availability prescribed	Actual % Availability	prescribed	time	Compensation paid (in Rs)
			(in days)	(in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL NIL		NIL
	NIL				