

NRSS-XXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of November 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Uri1(NHPC)-Amargarh(NRSS)-1	01/11/2023 00:00	01/12/2023 00:00	0:00	0:00	0:00	720:00	Continuously in ouatge from previous month. Shutdown availed by the NHPC -Uri Substation for Replacement of 400KV Oil filled cable with XLPE type Cable. Still not charged in this month.	100.00%
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	01/11/2023 00:00	01/12/2023 00:00	0:00	0:00	0:00	720:00	Continuously in ouatge from previous month. Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	06/11/2023 09:37	01/12/2023 00:00	0:00	0:00	0:00	590:23	Bus reactor taken out as per NRLDC instructions due to voltage regulation. Still not charged in this month.	

NRSS-XXIX Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of November 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of November 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL