

NRSS-XXIX Transmission Limited

I. AC Transmission Line Outage Details for the month of September 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee	Others	System constraint/ Natural calamity/ Militancy	Deemed Available		
			Hrs:Min	Hrs:Min	Hrs:Min	Hrs:Min		
400kV Amargarh(NRSS)-Wagoora(PG)-2	26/09/2023 09:49	26/09/2023 18:25	0:00	0:00	0:00	8:36	Shutdown availed by PGCIL for replacement of damaged insulators at Loc. 210. Only LILO section of Amargarh-Wagoora 3.46Kms belongs to the NRSS.	100.00%
400kV Uri1(NHPC)-Amargarh(NRSS)-1	27/09/2023 09:17	01/10/2023 00:00	0:00	0:00	0:00	86:43	Shutdown availed by the NHPC -Uri Substation for Replacement of 400KV Oil filled cable with XLPE type Cable. Still not charged in this month.	
400kV Uri1(NHPC)-Amargarh(NRSS)-2	21/09/2023 14:37	21/09/2023 17:09	2:32	0:00	0:00	0:00	The line tripped due to Y-phase to earth fault.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	01/09/2023 00:00	11/09/2023 04:35	0:00	0:00	0:00	244:35	Continuously in outage from previous month. Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	04/09/2023 10:35	11/09/2023 04:35	0:00	0:00	0:00	162:00	Bus reactor taken out as per NRLDC instructions due to voltage regulation.	
400 kV, 3-Ph 63 MVAR Bus Reactor-1 at Amargarh	29/09/2023 10:48	01/10/2023 00:00	0:00	0:00	0:00	37:12	Bus reactor taken out as per NRLDC instructions due to voltage regulation and continued for the month. Still not charged in this month.	
400 kV, 3-Ph 63 MVAR Bus Reactor-2 at Amargarh	29/09/2023 10:48	01/10/2023 00:00	0:00	0:00	0:00	37:12	Bus reactor taken out as per NRLDC instructions due to voltage regulation and continued for the month. Still not charged in this month.	

NRSS-XXIX Transmission Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of September 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of September 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL