

Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of December 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400/220 KV ICT-2 at Patran	01/12/2023 00:00	02/12/2023 21:30	45:30	0:00	0:00	0:00	Continuously under outage since last month. Shut Down availed by PTCL for attending 207 ICT-2 Bay B7 and B8 compartment SF6 gas leakage rectification work.	98.98%
400KV Patiala-Patran-1	12/12/2023 10:03	12/12/2023 18:48	0:00	0:00	0:00	8:45	Shutdown availed by PowerGrid for attending the defect rectification works.	
400KV Patiala-Patran-2	13/12/2023 10:29	13/12/2023 18:55	0:00	0:00	0:00	8:26	Shutdown availed by PowerGrid for attending the defect rectification works.	
400KV Patiala-Patran-1	19/12/2023 11:36	19/12/2023 17:08	0:00	0:00	0:00	5:32	Emergency Shutdown availed by PowerGrid to replace damage Polymer Insulator.	
400/220 KV ICT-1 at Patran	29/12/2023 12:29	29/12/2023 15:31	0:00	0:00	0:00	3:02	For replacement of existing energy meter by PSTCL.(Shutdown availed by SLC-Panjab)	
400/220 KV ICT-2 at Patran	29-12-2023 16:15	29-12-2023 17:41	0:00	0:00	0:00	1:26	For replacement of existing energy meter by PSTCL.(Shutdown availed by SLC-Panjab)	

**Patran Transmission Company Limited**

**II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of December 2023**

**Schedule II**

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

**III. Details of compensation paid by the inter-State transmission licensee for the month of December 2023**

**Schedule III**

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
<b>Total</b>					NIL