

Patran Transmission Company Limited

I. AC Transmission Line Outage Details for the month of November 2023

Schedule I

Element Name	Outage	Restoration	Duration of Outage Attributable to				Reason of Outage	% Availability
	Date Time	Date Time	Inter-State Transmission Licensee Hrs:Min	Others Hrs:Min	System constraint/ Natural calamity/ Militancy Hrs:Min	Deemed Available Hrs:Min		
400/220 KV ICT-2 at Patran	28/11/2023 09:10	01/12/2023 00:00	62:50	0:00	0:00	0:00	Shut Down availed by PTCL for attending 207 ICT-2 Bay B7 and B8 compartment SF6 gas leakage rectification work. The shutdown activity continued for the month.	98.55%
400KV Patiala-Patran-1	09/11/2023 10:41	09/11/2023 13:44	0:00	0:00	0:00	3:03	Shutdown availed by PowerGrid for attending the hotspot at hardware fitting at Loc. No. 242 Middle phase(B-Phase) of the line.	
400KV Kaithal -Patran-2			0:00	0:00	0:00	0:00	No Tripping/outage in this month	
400KV Patiala-Patran-2			0:00	0:00	0:00	0:00	No Tripping/outage in this month	
400/220 KV ICT-1 at Patran			0:00	0:00	0:00	0:00	No Tripping/outage in this month	
400KV Kaithal -Patran-1			0:00	0:00	0:00	0:00	No Tripping/outage in this month	

Patran Transmission Company Limited

II. Elements where restoration time has exceeded the standards specified in Regulation 5 (b) for the month of November 2023

Schedule II

Element Name	Restoration time as specified in Regulation 5 (b) (in days)	Actual restoration time (in days)
NIL	NIL	NIL
NIL	NIL	NIL
NIL	NIL	NIL

III. Details of compensation paid by the inter-State transmission licensee for the month of November 2023

Schedule III

Element Name	Violation of Regulation		Violation of Regulation 5(b)		Compensation paid (in Rs)
	% Availability prescribed	Actual % Availability	Restoration time prescribed (in days)	Actual restoration time (in days)	
NIL	NIL	NIL	NIL	NIL	NIL
NIL	NIL	NIL	NIL	NIL	NIL
Total					NIL